

BEFORE THE
ARKANSAS PUBLIC SERVICE COMMISSION

IN THE MATTER OF THE PETITION)
OF ENTERGY ARKANSAS, INC. FOR A)
DECLARATORY ORDER APPROVING)
REPLACEMENT OF THE STEAM) DOCKET NO. 98-065-U
GENERATORS AT ARKANSAS NUCLEAR)
ONE, UNIT 2, AND FOR AN ORDER)
APPROVING NEW DEPRECIATION RATES)
THEREON)

DIRECT TESTIMONY,

OF

DAVID A. SCHLISSEL,

SCHLISSEL TECHNICAL CONSULTING, INC.

ON BEHALF OF THE

GENERAL STAFF OF THE

ARKANSAS PUBLIC SERVICE COMMISSION

October 1998

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1 Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.

2 A. My name is David A. Schlissel. My business address is Schlissel Technical
3 Consulting, Inc., 45 Horace Road, Belmont, Massachusetts 02478.

4 Q. ON WHOSE BEHALF ARE YOU TESTIFYING IN THIS
5 PROCEEDING?

6 A. I am testifying on behalf of the General Staff of the Arkansas Public Service
7 Commission.

8 Q. PLEASE SUMMARIZE YOUR EDUCATIONAL BACKGROUND AND
9 RECENT WORK EXPERIENCE.

10 A. I graduated from the Massachusetts Institute of Technology in 1968 with a
11 Bachelor of Science Degree in Engineering. In 1969, I received a Master of
12 Science Degree in Engineering from Stanford University. In 1973, I
13 received a Law Degree from Stanford University. In addition, I studied
14 nuclear engineering at the Massachusetts Institute of Technology during the
15 years 1983-1986.

16 Since 1983 I have been retained by governmental bodies, publicly-
17 owned utilities, and private organizations in 24 states to prepare expert
18 testimony and analyses on engineering and economic issues related to electric
19 utilities. My clients have included the Staff of the California Public Utilities
20 Commission, the Staff of the Arizona Corporation Commission, the Staff of

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1 the Kansas State Corporation Commission, municipal utility systems in
2 Massachusetts, New York, Texas, and North Carolina, and the Attorney
3 General of the Commonwealth of Massachusetts.

4 I have testified before state regulatory commissions in Arizona, New
5 Jersey, Connecticut, Kansas, Texas, New Mexico, New York, Vermont,
6 North Carolina, South Carolina, Maine, Illinois, Indiana, Ohio,
7 Massachusetts, Missouri, and Wisconsin and before an Atomic Safety &
8 Licensing Board of the U.S. Nuclear Regulatory Commission.

9 A copy of my current resume is attached as Exhibit DAS-1.

10 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY IN THIS**
11 **DOCKET?**

12 **A. The General Staff of the Arkansas Public Service Commission retained**
13 **Schlissel Technical Consulting, Inc. ("STC") to analyze issues related to**
14 **Entergy's proposed replacement of the steam generators at the ANO Unit 2**
15 **Steam Generating Station. ("ANO 2") This testimony presents the results of**
16 **my investigation of these engineering and economic issues.**

17 **Q. PLEASE EXPLAIN HOW YOU HAVE CONDUCTED YOUR**
18 **INVESTIGATION OF ENTERGY'S PROPOSED REPLACEMENT OF**
19 **THE STEAM GENERATORS AT ANO 2.**

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1 A. I have completed the following activities as part of this investigation:

2 • I have submitted one hundred and thirty seven (137) detailed
3 interrogatories to Entergy and reviewed the more than twenty-five
4 thousand pages of documents that the Company provided in response
5 to these interrogatories. These documents included:

- 6
- 7 - the findings of steam generator tube inspections at ANO 2
- 8
- 9 - assessments of the root causes of steam generator tube
10 corrosion
- 11
- 12 - materials related to Entergy's efforts to address steam generator
13 tube corrosion at ANO 2 including the minutes of Company
14 task forces and committees
- 15
- 16 - engineering and economic analyses of Entergy's options for
17 addressing steam generator corrosion
- 18
- 19 - materials related to Entergy's participation in steam generator-
20 related industry groups and visits by ANO 2 engineers to other
21 power plants
- 22
- 23 - assessments of the likely future progress of steam generator
24 tube degradation
- 25
- 26 - economic studies of the optimum date for replacing the ANO
27 2 steam generators
- 28
- 29 - materials related to the design and materials features of the
30 replacement steam generators
- 31
- 32 - materials related to the selection of the contractors for the ANO
33 2 Steam Generator Replacement Contract
- 34
- 35 - materials related to the Company's efforts to preplan and
36 prepare for the replacement of the ANO 2 steam generators

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

- 1 • I have met with the manager of Entergy's ANO-2 Steam Generator
2 Replacement Project and with three other engineers who have been
3 involved with the Company's efforts to address steam generator tube
4 degradation at the plant and to study whether replacement was the
5 most cost-effective alternative.
6
7 • I have reviewed the extensive correspondence between the U.S.
8 Nuclear Regulatory Commission ("NRC") and Entergy concerning
9 steam generator related corrosion issues and the results of periodic
10 NRC inspections and evaluations of ANO 2.
11
12 • I have reviewed the nuclear industry experience concerning steam
13 generator tube corrosion and the replacement of the steam generators
14 at both domestic U.S. and foreign nuclear power plants.
15
16 • I have analyzed the economic studies presented in the testimony of
17 Company witness Kenney and, with the assistance of the APSC
18 General Staff, I have prepared sensitivity analyses using the
19 Company's economic model.
20

21 **Q. HAVE YOU EVALUATED THE REPLACEMENT OF THE STEAM**
22 **GENERATORS AT OTHER OPERATING NUCLEAR POWER**
23 **PLANTS?**

24 **A. Yes. I have evaluated the engineering and economic reasonableness of the**
25 **proposed replacement of the steam generators at the Trojan, Indian Point**
26 **Unit No. 2, and Point Beach Unit No. 2 nuclear power plants. I also have**
27 **evaluated the reasonableness of Northeast Utilities' planning for and**
28 **management of the replacement of the steam generators at the Millstone Unit**
29 **No. 2 nuclear plant.**

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1 In addition, I have examined steam generator-related design and
2 materials issues in a number of other investigations of nuclear power plant
3 construction projects and operating facilities.

4 **Q. PLEASE SUMMARIZE YOUR CONCLUSIONS.**

5 **A.**Based on the information that I have reviewed and the economic sensitivity
6 studies that I have prepared, I agree with the Company that it is necessary
7 to replace the steam generators at ANO 2 and that replacement appears to be
8 the least cost option at this time.

9 **Q. WHAT WERE THE ROOT CAUSES OF THE STEAM GENERATOR**
10 **TUBE PROBLEMS THAT HAVE BEEN EXPERIENCED AT ANO 2?**

11 **A.**The root cause of the tube degradation experienced at ANO 2 was the
12 susceptibility of the materials used in the existing steam generators to
13 corrosion when exposed to the operating environment in the steam
14 generators. In particular, the Alloy 600 material used for the steam
15 generator tubes has been shown to be extremely susceptible to a variety of
16 degradation mechanisms including denting, stress corrosion cracking, and
17 intergranular attack.

18 **Q. WERE THE MATERIALS USED IN THE ORIGINAL ANO 2 STEAM**
19 **GENERATORS TYPICAL OF THE TYPES OF MATERIALS USED**
20 **IN STEAM GENERATORS BUILT IN THE 1970'S?**

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1 A. Yes. The materials used in the ANO 2 steam generators, including the
2 Alloy 600 material used for the steam generator tubes, were typical of the
3 materials used in nuclear power plants of ANO 2's vintage.

4 **Q. WHO DESIGNED THE ORIGINAL ANO 2 STEAM GENERATORS?**

5 A. The original steam generators were included in ANO 2's Nuclear Steam
6 Supply System ("NSSS") which was designed and supplied to the Company
7 by Combustion Engineering.

8 **Q. HAVE ANY UTILITIES SUED COMBUSTION OVER PROBLEMS**
9 **EXPERIENCED BY STEAM GENERATORS?**

10 A. Yes. Florida Power & Light Corporation sued Combustion Engineering in
11 1995, saying that the steam generators at the St. Lucie Unit 1 nuclear plant
12 had lasted only one-half as long as Combustion Engineering had promised.
13 The two parties reached a confidential settlement in March, 1997.

14 **Q. HAS ENTERGY SUED COMBUSTION ENGINEERING OVER THE**
15 **PROBLEMS EXPERIENCED BY THE ANO 2 STEAM**
16 **GENERATORS?**

17 A. No. I have been informed that the Company has reached a settlement with
18 Combustion Engineering in lieu of litigation. However, the General Staff
19 has not yet been informed of the terms of that settlement but it is possible
20 that any compensation that the Company may have received from

**ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL**

1 Combustion Engineering could have ratemaking implications which are
2 beyond the scope of this docket.

3 **Q. HAS THE STEAM GENERATOR TUBE-RELATED CORROSION**
4 **THAT HAS BEEN EXPERIENCED AT ANO 2 BEEN TYPICAL OF**
5 **THE CORROSION EXPERIENCED AT OTHER OPERATING**
6 **NUCLEAR POWER PLANTS?**

7 **A.** Yes. Essentially all of the operating nuclear power plants in the U.S. have
8 experienced some degree of steam generator tube corrosion. However, the
9 specific degradation mechanisms experienced and the number of tubes with
10 defects have varied significantly from plant to plant.

11 **Q. WHICH OPERATING POWER PLANTS IN THE U.S. HAVE HAD**
12 **STEAM GENERATORS DESIGNED BY COMBUSTION**
13 **ENGINEERING?**

14 **A.** The following nuclear plants have had steam generators that were originally
15 supplied as part of NSSS systems from Combustion Engineering – ANO 2,
16 Calvert Cliffs, Fort Calhoun, Maine Yankee, Millstone Unit 2, Palisades,
17 Palo Verde Units 1, 2, and 3, San Onofre Units 2 and 3, St. Lucie Units 1
18 and 2 and Waterford Unit 3.

19 **Q. HAVE THE SPECIFIC STEAM GENERATOR TUBE CORROSION**
20 **MECHANISMS THAT HAVE BEEN EXPERIENCED AT ANO 2**

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1 **BEEN TYPICAL OF THE MECHANISMS THAT HAVE AFFECTED**
2 **THESE OTHER NUCLEAR PLANTS WITH COMBUSTION**
3 **ENGINEERING DESIGNED STEAM GENERATORS?**

4 A. Yes. The corrosion mechanisms that have been experienced at ANO 2 are
5 typical of the mechanisms that have degraded the steam generator tubes at
6 other plants with Combustion Engineering designed steam generators. For
7 example, the denting of steam generator tubes at the tube support plates that
8 affected ANO 2 during the early to mid-1980's, also was experienced at the
9 Calvert Cliffs, St. Lucie 1 and Fort Calhoun nuclear plants. Similarly, the
10 outer diameter stress corrosion cracking/intergranular attack at the top of the
11 tube sheet and the tube support plates that has affected ANO 2 since the
12 early 1990's has been reported as a problem at Calvert Cliffs, St. Lucie Unit
13 1, Maine Yankee, and Fort Calhoun.

14 **Q. HAS TUBE CORROSION LED TO THE REPLACEMENT OF THE**
15 **STEAM GENERATORS AT OTHER OPERATING NUCLEAR**
16 **POWER PLANTS IN THE U.S.?**

17 A. Yes. As shown on Table STC-1 below, steam generator tube corrosion has
18 led to the replacement of the steam generators at twenty-one nuclear power
19 plants in the U.S. and at many foreign plants. Steam generators also are

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1 currently being replaced at Commonwealth Edison Company's Braidwood
 2 Station in Illinois.

3 TABLE STC-1
 4 DURATIONS OF DOMESTIC U.S.
 5 STEAM GENERATOR REPLACEMENT OUTAGES

<u>Plant</u>	<u>Year Replacement Completed</u>	<u>Duration of Replacement Outage</u>
Surry 2	1980	260 days
Surry 1	1981	200 days
Turkey Point 3	1982	217 days
Turkey Point 4	1983	150 days
Point Beach 1	1984	118 days
Robinson 2	1984	130 days
Cook 2	1989	175 days
Indian Point 3	1989	140 days
Palisades	1991	121 days
Millstone 2	1993	228 days
North Anna 1	1993	96 days
Summer 1	1994	99 days
North Anna 2	1995	68 days
Ginna	1996	70 days
Catawba 1	1996	115 days
Salem 1	1997	Unquantified ¹

¹ The replacement of the Salem Unit 1 steam generators was performed as part of a 2-3 year outage during which the utility

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1	McGuire 1	1997	94 days
2	St. Lucie 1	1997	79 days
3	Point Beach 2	1997	Unquantified ²
4	McGuire 2	1997	77 days
5	Byron 1	1998	105 days
6	Braidwood 1	1998	ongoing

7

8 **Q. HAVE STEAM GENERATORS DESIGNED BY COMBUSTION**
9 **ENGINEERING BEEN REPLACED AT ANY POWER PLANTS?**

10 **A.** Yes. The steam generators have been replaced at the Palisades, Millstone
11 Unit 2 and St. Lucie Unit 1 nuclear plants, all of which had Combustion
12 Engineering designed steam generators. Replacement steam generators also
13 have been ordered for the Calvert Cliffs and Palo Verde plants.

addressed significant management, programmatic, and hardware deficiencies. Thus, it is not possible to identify a separate duration for the steam generator replacement outage.

2

The replacement of the steam generators at Point Beach Unit 2 was performed at the beginning of a ten-month outage during which the utility addressed serious concerns that had been raised by the U.S. Nuclear Regulatory Commission. Thus, it is not possible to identify a separate duration for the steam generator replacement outage.

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1 Q. HAVE STEAM GENERATOR RELATED PROBLEMS LED TO THE
2 RETIREMENTS OF ANY OPERATING NUCLEAR POWER
3 PLANTS?

4 A. Yes. The cost of addressing steam generator corrosion issues was a major
5 factor in the decisions to retire the Maine Yankee, San Onofre Unit 1, and
6 Trojan nuclear plants.

7 Q. DO YOU AGREE WITH THE CONCLUSION OF COMPANY
8 WITNESS DOUGHTY THAT ENTERGY RESPONDED
9 REASONABLY TO ANO 2 STEAM GENERATOR CORROSION
10 ISSUES?

11 A. Yes. The extensive documentation that I have reviewed shows that, overall,
12 the Company responded to steam generator corrosion issues appropriately.
13 In particular, the Company created a Steam Generator Task Force in 1981
14 and a Steam Generator Integrity Committee in 1985 to monitor the
15 performance of the steam generators and to investigate potential corrective
16 actions for corrosion issues. These organizations identified and evaluated
17 potential remedies for steam generator tube corrosion, including a number
18 of plant modifications and changes to plant water chemistry that were
19 ultimately implemented by management.

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1 The Company also regularly incorporated lessons learned from the
2 experiences of other utilities in addressing steam generator corrosion issues.
3 As part of this effort, Company representatives attended the Electric Power
4 Research Institute's ("EPRI") conferences on steam generator issues and
5 participated in industry organizations such as the Combustion Engineering
6 Owners Group Steam Generator Task Force and the EPRI Steam Generator
7 Strategic Management Group. In addition, Company engineers regularly
8 reviewed steam generator-related issuances from the NRC and the Institute
9 of Nuclear Power Operations ("INPO") for information applicable to ANO
10 2.

11 **Q. IS THERE ANY EVIDENCE THAT THE STEAM GENERATOR**
12 **TUBE DEGRADATION AT ANO 2 WAS MADE MORE SEVERE DUE**
13 **TO THE COMPANY'S OPERATIONAL PRACTICES?**

14 **A. No. I have seen no evidence that suggests that Entergy's operational**
15 **practices made the steam generator tube corrosion at ANO 2 more severe.**

16 **Q. WERE THERE ANY REASONABLE ACTIONS THAT ENTERGY**
17 **COULD HAVE TAKEN THAT WOULD HAVE ENABLED THE**
18 **COMPANY TO AVOID STEAM GENERATOR TUBE CORROSION?**

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1 A. No. Given the experience of other operating nuclear power plants of a
2 similar vintage, both in the U.S. and abroad, it was almost inevitable that
3 ANO 2 would experience significant steam generator tube corrosion.

4 **Q. HAS THE NRC EXPRESSED ANY SERIOUS CONCERNS ABOUT**
5 **THE ACTIONS TAKEN BY ENTERGY CONCERNING THE STEAM**
6 **GENERATORS AT ANO 2?**

7 A. NRC evaluations of Entergy's steam generator practices at ANO 2 generally
8 have been positive except for negative findings in 1992 and 1996 which were
9 limited to deficiencies in the Company's tube inspection programs.

10 **Q. WHEN DID THE COMPANY START TO ANALYZE WHETHER IT**
11 **MIGHT NEED TO REPLACE THE ANO 2 STEAM GENERATORS?**

12 A. The Company first began in 1992 to find large numbers of tubes with axial
13 cracks at the tube support plates and/or circumferential cracks at the top of
14 the tube sheet. It appears that the discovery of these cracks led the Company
15 to seriously consider that the ANO 2 steam generators might have to be
16 replaced.

17 **Q. DID THE COMPANY USE A REASONABLE DECISION-MAKING**
18 **PROCESS TO REACH THE CONCLUSION THAT THE ANO 2**
19 **STEAM GENERATORS SHOULD BE REPLACED?**

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1 A. Yes. The Company conducted several detailed engineering and economic
2 analyses during the years 1993 through 1996 that formed the basis for the
3 decision to replace the ANO 2 steam generators during the unit's year 2000
4 refueling outage. These studies, which were assisted by experienced
5 consulting firms, used a steam generator strategic model which examined
6 likely future steam generator tube degradation rates at ANO 2 and a wide
7 variety of alternative repair or replacement scenarios.

8 **Q. PLEASE DESCRIBE THE ALTERNATIVE REPAIR AND**
9 **REPLACEMENT SCENARIOS CONSIDERED BY THE COMPANY**
10 **IN THESE ENGINEERING AND ECONOMIC ANALYSES.**

11 A. The Company's 1993 analyses investigated the following questions:

- 12 • Will the Company need to replace the steam generators? If so, will
13 the replacements last until 2038?
- 14 • How much will the Company spend on repair or replacement? And
15 when?
- 16 • What should the Company do now? What actions can be deferred?
- 17 • Is there any way to avoid replacement? If so, under what conditions,
18 and how likely are they?
- 19
- 20
- 21
- 22

23 To answer these questions, the studies looked at a broad range of
24 alternative repair and replacement options, including:

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

- 1 • different repair methods – plugging, sleeving and preventive
2 sleeving.
- 3
- 4 • different plant primary system operating temperatures between 590
5 and 607 degrees.
- 6
- 7 • the optimal date(s) for steam generator replacement.
- 8
- 9 • whether to seek NRC permission to use Alternative Plugging Criteria
10 for the axial cracks at the tube support plates.
- 11
- 12 • whether to restore previously plugged tubes to service.³
13

14 The 1993 studies also considered a number of related Operating
15 Enhancements which included replacing the ANO 2 condenser and Moisture
16 Separator Reheater, increasing the thermal power of the plant, and chemical
17 cleaning of the steam generators.

18 **Q. WHAT WERE THE PRIMARY CONCLUSIONS OF THE**
19 **COMPANY’S 1993 STUDIES?**

20 **A.** The primary conclusion of the 1993 Company studies was that the steam
21 generators should be replaced in the 2000-2003 time frame because
22 replacement could not be avoided unless the steam generator tube
23 degradation rate turned “optimistic.” The studies also concluded that the

³

The options considered by the Company are listed on a page from the 1993 studies which is included as Exhibit DAS-2.

**ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL**

1 Company should replace the ANO 2 condenser and perform the primary side
2 power uprating with the steam generator replacement and that the Moisture
3 Separator Reheater should be replaced as soon as possible. The studies
4 further found that, in the years prior to replacement, the Company should
5 maintain the primary system hot leg water temperature at 599 degrees and,
6 where possible, insert sleeves to repair tube defects.

7 **Q. IN SUBSEQUENT YEARS DID THE COMPANY REEVALUATE THE
8 NEED TO REPLACE THE ANO 2 STEAM GENERATORS?**

9 **A. Yes. The Company reexamined the options for addressing steam generator
10 corrosion in subsequent years, including whether replacement of the steam
11 generators was the most economic alternative. These studies looked at
12 changed circumstances, including revised predictions of the likely future
13 course of steam generator tube degradation that reflected the discovery of
14 additional tube cracks during the years 1994 and 1995.**

15 **Q. WHAT WERE THE CONCLUSIONS OF THESE SUBSEQUENT
16 COMPANY REEXAMINATIONS OF WHETHER TO REPLACE THE
17 ANO 2 STEAM GENERATORS?**

18 **A. As shown in Exhibit JFK-2 of Entergy witness Kenney, the Company's
19 subsequent economic studies continued to show that replacement of the**

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1 steam generators was cost-effective and should be planned for the years
2 2001-2003.

3 **Q. DO YOU AGREE WITH THE ENTERGY CONCLUSION THAT THE**
4 **ANO 2 STEAM GENERATORS WILL HAVE TO BE REPLACED IN**
5 **THE YEAR 2000?**

6 **A.** Yes. Entergy's recent engineering analyses show that the NRC-approved
7 tube plugging limit of 30 percent for ANO 2 will be reached during the
8 unit's refueling outage in the year 2000, assuming pessimistic (i.e., high)
9 tube degradation rates. The Company's studies also show that the unit will
10 be near its NRC-approved 30 percent steam generator tube plugging limit
11 during that outage even if the tubes only degrade at the optimistic (i.e.,
12 lower) rate.

13 **Q. DO YOU BELIEVE IT IS APPROPRIATE TO ASSUME**
14 **PESSIMISTIC TUBE DEGRADATION RATES WHEN SCHEDULING**
15 **THE REPLACEMENT OF THE STEAM GENERATORS?**

16 **A.** Yes. There could be significant cost consequences if the Company delays
17 the planned steam generator replacement to a subsequent ANO 2 outage
18 based on optimistic tube degradation rates and then is forced to plug a larger
19 than expected number of tubes during the year 2000 outage. Under those
20 circumstances, Entergy probably would be required to maintain ANO 2 shut

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1 down until the replacement steam generators had arrived and all pre-outage
2 planning and preparations had been completed. Such an outage could last
3 months, if not longer. The unavailability of ANO 2 for such an extended
4 period would lead to higher replacement power costs for both the Company
5 and its ratepayers.

6 An internal Company memorandum likened planning the date for
7 replacing the ANO 2 steam generators based on optimistic degradation rates
8 to “running out of gas as you roll into the gas station” and noted that this
9 was a “very risky scenario especially if the consequences were great (i.e.,
10 unable to start up after the 2001 outage).” The memorandum also noted that
11 such a strategy provided “no hedge against the variability in the degradation
12 projections.” I agree.

13 **Q. DO YOU AGREE WITH THE CONCLUSION OF COMPANY**
14 **WITNESS DOUGHTY THAT THE SELECTION OF BECHTEL TO**
15 **REMOVE THE ORIGINAL STEAM GENERATORS AND INSTALL**
16 **THE NEW STEAM GENERATORS WAS CONSISTENT WITH**
17 **INDUSTRY PRACTICE?**

18 **A.** Yes. The selection of Bechtel was a reasonable choice. Bechtel has had
19 extensive experience in managing and conducting the replacement of steam
20 generators at operating nuclear power plants. In fact, at the time that

**ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL**

1 Entergy chose the contractors for the ANO 2 steam generator replacement
2 project, Bechtel had served as the primary contractor on 11 of the 16
3 domestic U.S. steam generator replacements that had been completed
4 through 1996. Bechtel has also served as the primary contractor on all four
5 of the steam generator replacements which have required temporary cuts to
6 be made in the plant's containment building to remove the original steam
7 generators and to install the replacement equipment. Such a temporary cut
8 in the containment will be required to replace ANO 2's steam generators.

9 In addition, Bechtel had been the architect engineer/constructor for
10 ANO 2 and had provided support engineering services for the unit in recent
11 years.

12 **Q. DO YOU AGREE WITH THE CONCLUSION OF COMPANY**
13 **WITNESS DOUGHTY THAT THE SELECTION OF**
14 **WESTINGHOUSE TO MANUFACTURE THE ANO 2**
15 **REPLACEMENT STEAM GENERATORS WAS CONSISTENT WITH**
16 **INDUSTRY PRACTICE?**

17 **A. Yes. Westinghouse has designed and manufactured the replacement steam**
18 **generators for twelve domestic nuclear power plants.**

19 **Q. DO YOU HAVE ANY OBSERVATIONS ON THE PROCESS THE**
20 **COMPANY USED TO SELECT BECHTEL AND WESTINGHOUSE?**

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1 A. Yes. The documents provided by Entergy during discovery reveal that the
2 Company implemented a very thorough process for selecting the contractors
3 for the manufacture and installation of the ANO 2 replacement steam
4 generators. This process included the submission of Requests for Proposals
5 to potential bidders; the review of proposals; the acceptance of rebids; the
6 review by an ANO 2 Replacement Steam Generator Bid Evaluation Core
7 Team; meetings with and presentations by bidders; input from ANO Bid
8 Evaluation Team Specialty Area Members; and the review of additional
9 information provided in response to bid related questions. The Company
10 also created a Vendor Evaluation Team which visited other steam generator
11 replacement outages and the fabrication facilities of each of the bidders to
12 design and supply the replacement steam generators.

13 **Q. DO THE MATERIALS AND DESIGN FEATURES OF THE**
14 **REPLACEMENT STEAM GENERATOR ADDRESS THE STEAM**
15 **GENERATOR CORROSION MECHANISMS THAT HAVE**
16 **DEGRADED THE ORIGINAL ANO 2 STEAM GENERATORS?**

17 A. Yes. Many design and materials improvements have been incorporated in
18 the replacement steam generators to be installed at ANO 2 to minimize their
19 susceptibility to the corrosion mechanisms that have affected the original
20 steam generators. Most significantly, the replacement steam generators will

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1 use Alloy 690 tubes. This material offers a superior resistance to corrosion
2 in steam generator operating environments. The replacement steam
3 generators also will use stainless steel for tube support plates. This will
4 enhance their resistance to the denting suffered by the carbon steel tube
5 support plates in the original steam generators.

6 **Q. WHAT HAS BEEN THE OPERATING PERFORMANCE OF OTHER**
7 **REPLACEMENT STEAM GENERATORS WITH ALLOY 690 TUBES?**

8 A. Replacement steam generators with Alloy 690 tubes have been in service
9 since March 1989. During this 9.5 year period, there have been no reports
10 of any Alloy 690 tubes that have been plugged due to in-service degradation.
11 The only defects in tubes manufactured from Alloy 690 have been caused by
12 damage during maintenance operations.

13 **Q. WHAT IS THE PROJECTED SERVICE LIFE FOR THE**
14 **REPLACEMENT STEAM GENERATORS?**

15 A. Entergy's Steam Generator Replacement Specifications require that the
16 cumulative full power operating life of the replacement steam generators to
17 be provided by Westinghouse be forty years.

18 **Q. WHAT IMPACT WILL THE REPLACEMENT OF THE ANO 2**
19 **STEAM GENERATORS HAVE ON THE POSSIBILITY OF**
20 **EXTENDING THE UNIT'S OPERATING LIFE?**

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1 A. The installation of the replacement steam generators will enhance the
2 Company's ability to extend the operating life of ANO 2 beyond the unit's
3 currently scheduled retirement in 2018.

4 **Q. DO YOU HAVE ANY OBSERVATIONS CONCERNING THE**
5 **COMPANY'S EFFORTS TO PREPLAN THE REPLACEMENT OF**
6 **THE ANO 2 STEAM GENERATORS?**

7 A. Yes. It appears that the Company is taking reasonable steps to preplan the
8 steam generator replacement. In addition to selecting Bechtel and
9 Westinghouse, Entergy has retained ABB-Combustion Engineering, the
10 designer of the ANO 2 nuclear steam supply system, to provide licensing
11 support and safety analyses. The Company also appears to be making
12 reasonable efforts to monitor the work of these project contractors. These
13 efforts include the placement of a full-time on-site representative at the
14 ENSA facility in Spain where the replacement steam generators are being
15 fabricated.

16 The documentation that I have reviewed shows that the Company also
17 is making an extensive effort to learn from the experiences of the steam
18 generator replacements at other nuclear power plants. In addition to
19 retaining Bechtel and other contractors with significant experience in
20 replacing steam generators, Company engineers have visited the replacement

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1 outages at the St. Lucie Unit 1, Ginna, Catawba Unit 1, Byron, Braidwood,
2 and Point Beach Unit 2 plants. The Company also has participated in the
3 industry Steam Generator Replacement Group.

4 **Q. IS THE COMPANY'S PROJECTED 70 TO 75 DAY DURATION FOR**
5 **THE ANO 2 STEAM GENERATOR REPLACEMENT OUTAGE**
6 **CONSISTENT WITH THE DURATIONS OF THE STEAM**
7 **GENERATOR REPLACEMENT OUTAGES AT OTHER NUCLEAR**
8 **POWER PLANTS?**

9 **A.** Yes. The Company's projected outage is consistent with the durations of
10 recent steam generator replacement outages which are shown on Table STC-
11 1 earlier in my testimony.

12 **Q. IS THE COMPANY'S PROJECTED COST FOR THE REMOVAL OF**
13 **THE ORIGINAL STEAM GENERATORS AND THE INSTALLATION**
14 **OF THE REPLACEMENT STEAM GENERATORS CONSISTENT**
15 **WITH THE COST OF STEAM GENERATOR REPLACEMENTS AT**
16 **OTHER NUCLEAR POWER PLANTS?**

17 **A.** Yes. Entergy's projected cost for the ANO 2 steam generator replacement
18 is based on detailed cost estimates and contracts with project contractors and
19 is within the \$100 to \$200 million range that recent steam generator
20 replacements have cost.

**ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL**

1 Q. HAVE YOU FOUND ANY WEAKNESSES IN THE ENTERGY 1998
2 ECONOMIC ANALYSIS PRESENTED BY COMPANY WITNESS
3 KENNEY?

4 A. Yes. The Company fails to present any sensitivity studies which examine
5 the economics of replacing the steam generators.

6 Q. HAVE YOU PREPARED ANY SENSITIVITY STUDIES TO
7 EXAMINE THE ECONOMICS OF REPLACING THE ANO 2 STEAM
8 GENERATORS IF YOU ASSUME THAT THE COMPANY'S
9 PROJECTIONS FOR FUTURE ANO 2 OPERATING PERFORMANCE
10 AND COSTS ARE NOT MET?

11 A. Yes. Using the Company's economic model, and with the assistance of the
12 APSC General Staff, I have prepared sensitivity scenarios which assume
13 84.5 percent, 78.7 percent, and 71.7 percent for the three-year rolling
14 average capacity factors for ANO 2 following the completion of the steam
15 generator replacement outage. I also have prepared sensitivity scenarios
16 which assume that future ANO 2 O&M costs after the steam generators are
17 replaced will be 10 percent higher than the Company's Base Case figures.

18 Q. ON WHAT BASIS DID YOU DECIDE TO PREPARE SENSITIVITY
19 SCENARIOS FOR THREE-YEAR ROLLING AVERAGE CAPACITY
20 FACTORS OF 84.5 PERCENT, 78.7 PERCENT AND 71.7 PERCENT?

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1 A. ANO 2 achieved a 78.7 percent capacity factor during the ten-year period
2 1988-1997 and an 84.5 percent capacity factor during the five- year period
3 1993-1997. ANO 2's cumulative lifetime capacity factor through the end of
4 1997 was 71.7 percent.

5 **Q. WHAT WERE THE RESULTS OF YOUR SENSITIVITY STUDIES?**

6 A. The results of my sensitivity studies are shown on Table STC-2 below. All
7 of these studies use the Company's base case assumptions except for the
8 changed capacity factors and O&M costs:

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

TABLE STC-2
Sensitivity Scenarios
Net Present Value Benefit of
Replacing the ANO 2 Steam Generators
Versus No Replacement

Scenario			
Future Market Price of Power	Future ANO 2 Capacity Factor	Future ANO 2 O&M Costs	NPV Benefit of Replacement (\$1000)
High	84.5 percent	Base Case	
High	78.7 percent	Base Case	
High	71.7 percent	Base Case	
Low	84.5 percent	Base Case	
Low	78.7 percent	Base Case	
Low	71.7 percent	Base Case	
High	Base Case	+ 10 percent	
High	84.5 percent	+ 10 percent	
High	78.7 percent	+ 10 percent	
High	71.7 percent	+ 10 percent	
Low	Base Case	+ 10 percent	
Low	84.5 percent	+ 10 percent	
Low	78.7 percent	+ 10 percent	
Low	71.7 percent	+ 10 percent	

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1
2
3

TABLE STC-3
Aging Sensitivity Scenarios
Net Present Value Benefit of

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1 **Q.** **HAVE YOU PREPARED ANY OTHER SENSITIVITY STUDIES?**

2 A. Yes. I have prepared a number of scenarios to examine what would happen
3 if ANO 2's future operating performance declines dramatically and if the
4 unit's O&M costs increase significantly after the unit reaches the age of 30.

5 I assumed for these scenarios that ANO 2 achieves the Company's
6 Base Case capacity factor and O&M projections through the year 2009. I
7 then assumed that the unit's three-year rolling capacity factor would drop to
8 60 percent and O&M costs would increase by 20 percent for the remaining
9 9 years of its operating life. Although operating performance and O&M
10 expenditures would probably change more gradually as a plant ages, these
11 scenarios provide dramatic examples of what could happen.

12 **Q.** **WHAT WERE THE RESULTS OF THESE AGING SCENARIOS?**

13 A. The results of these scenarios are shown on Table STC-3 below:

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

TABLE STC-3
 Aging Sensitivity Scenarios
 Net Present Value Benefit of
 Replacing the ANO 2 Steam Generators
 Versus No Replacement

<u>Scenario</u>		
<u>Future Market Price of Power</u>	<u>Future ANO 2 Capacity Factor</u>	<u>NPV Benefit of Replacement (\$1000)</u>
High		
High		
Low		
Low		

These scenarios show that replacement of the ANO 2 steam generators would remain the lowest cost option even if you assume that aging will adversely impact the unit's performance and costs.

Q. WHAT IS YOUR OVERALL CONCLUSION REGARDING ENTERGY'S PROPOSAL TO REPLACE THE STEAM GENERATORS AT ANO 2?

A. Based on the information I have reviewed and the sensitivity studies that I have prepared, I agree with the Company that it is necessary to replace the steam generators at ANO 2 and that replacement appears to be the least cost option at this time.

ENTERGY ARKANSAS, INC.
DOCKET NO. 98-065-U
PREPARED TESTIMONY OF DAVID A. SCHLISSEL

1 Q. DOES THIS COMPLETE YOUR TESTIMONY?

2 A. Yes.