

BEFORE THE NEW MEXICO PUBLIC REGULATION COMMISSION

IN THE MATTER OF PUBLIC SERVICE
COMPANY OF NEW MEXICO'S
ABANDONMENT OF SAN JUAN
GENERATING STATION UNITS 1 AND 4

Case No. 19-00018-UT

PUBLIC SERVICE COMPANY OF NEW
MEXICO

Applicant

Prepared Rebuttal Testimony of David A. Schlissel

On Behalf Of

Sierra Club

NOVEMBER 15, 2019

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

TABLE OF CONTENTS

I.	Introduction.....	1
II.	It is Extremely Unrealistic to Assume that a Retrofitted SJGS Would Capture 6 Million Metric Tonnes of CO ₂ Per Year.....	6
	A. A Retrofitted SJGS Cannot Be Expected to Operate at an 85% to 100% Annual Capacity Factor for An Extended Number of Years.....	7
	B. 90% CO ₂ Capture Has Not Been Proven.....	18
III.	Retrofitting SJGS for CO ₂ Capture is Likely to be Much More Expensive than Enchant and S&L are Claiming	33
IV.	It is Extremely Unlikely that a Retrofit of SJGS Could be Completed and Come Online before 2024	39
V.	The Cost of Capturing CO ₂ at SJGS Can Be Expected to be Much Higher Than Enchant and S&L Are Claiming	44
VI.	The Owner(s) of SJGS Can Expect to Suffer Substantial Losses in the Sale of Electricity	47
VII.	The Owner(s) of SJGS Would Be Exposed to Oil Market Volatility and Risks ..	51
VIII.	Conclusions	53

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 I. Introduction

2 Q. Please state your name and business address.

3 A. My name is David A. Schlissel. I am the President of Schlissel Technical
4 Consulting, Inc. My business address is 45 Horace Road, Belmont, MA 02478.

5 Q. On whose behalf are you testifying?

6 A. I am testifying on behalf of Sierra Club.

7 Q. Please summarize your educational background and recent work experience.

8 A. I graduated from the Massachusetts Institute of Technology in 1968 with a
9 Bachelor of Science Degree in Engineering. In 1969, I received a Master of
10 Science Degree in Engineering from Stanford University. In 1973, I received a
11 Law Degree from Stanford Law School. In addition, I studied nuclear engineering
12 at the Massachusetts Institute of Technology during the years 1983-1986.

13 Since 1983 I have been retained by governmental bodies, publicly owned utilities,
14 and private organizations in 38 states to prepare expert testimony and analyses on
15 engineering, economic and financial issues related to electric utilities. My clients
16 have included state utility commissions, attorneys general, and consumer
17 advocates, publicly owned utilities, and local, national and international
18 environmental and consumer organizations.

19 I have filed expert testimony before state regulatory commissions in Arizona,
20 Arkansas, California, Colorado, Connecticut, Florida, Georgia, Illinois, Indiana,
21 Iowa, Kansas, Louisiana, Maine, Maryland, Massachusetts, Michigan, Minnesota,
22 Mississippi, Missouri, Montana, New Jersey, New Mexico, New York, North
23 Carolina, North Dakota, Ohio, Oregon, Rhode Island, South Carolina, South
24 Dakota, Texas, Vermont, Virginia, West Virginia, and Wisconsin; before the U.S.
25 Federal Energy Regulatory Commission and Atomic Energy Commission; and in
26 state and federal court proceedings.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 A copy of my current resume is included as Attachment DAS-1. Additional
2 information about my work is available at www.schlissel-technical.com and
3 www.ieefa.org.

4 **Q. Have you previously testified before this Commission?**

5 A. Yes. I testified before the New Mexico Public Regulation Commission in Case
6 2146, Part II. I also prepared a report in Case No. 05-00275-UT as a consultant to
7 the Commission.

8 **Q. What is the purpose of your testimony in this proceeding?**

9 A. I have been asked to evaluate whether retrofitting San Juan Generating Station
10 (SJGS) with a system to capture the plant's carbon dioxide emissions, compress
11 the captured CO₂ and then sell it to oil companies for use in enhanced oil recovery
12 activities is a feasible scenario as Public Regulation Commission Staff witness
13 Dhiraj Solomon has testified.

14 **Q. Please explain the rationale behind carbon capture and storage or reuse**
15 **(CCS or CCUS).**

16 A. Coal-fired electric generation facilities emit large quantities of CO₂ during
17 operation. According to the Energy Information Administration, a unit of the
18 Department of Energy, coal plants in the U.S. released 1,150 million metric tons
19 of CO₂ in 2018, accounting for 65% of the electric generation sector's total CO₂
20 emissions nationwide.¹ At the same time, coal only supplied 28% of the electricity
21 generated during the year. This mismatch has become increasingly problematic
22 for the industry as concerns about climate change have grown and cleaner
23 alternatives, particularly zero-carbon renewable options such as wind and solar,
24 have become commercially viable.

¹ U.S. Energy Information Administration, "How much of U.S. carbon dioxide emissions are associated with electricity generation?", available at <https://www.eia.gov/tools/faqs/faq.php?id=77&t=11>.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 To address these concerns, some coal industry proponents have been pushing for
2 the development of systems that can capture the fuel's carbon emissions, and
3 either store that captured carbon underground or reuse it in other applications,
4 particularly to improve the amount of oil recovered from older producing sites.

5 Despite billions of dollars of federal research funds, only one such carbon capture
6 project has been built at a coal-fired electric power facility in the U.S. – the Petra
7 Nova project in Texas. A second, smaller carbon capture unit is also in operation
8 in Canada at Boundary Dam Unit 3. Both of these projects, as I will show later,
9 have failed to meet their promised performance goals, undercutting assertions by
10 backers of the SJGS CCS retrofit that they will be using commercially proven
11 technology.

12 **Q. Please summarize your findings.**

13 **A.** My main findings are as follows:

- 14 1. Contrary to Mr. Solomon's testimony, continuing to operate SJGS after
15 being retrofitted for CCS is not a feasible financial or economic scenario
16 and is not a plausible scenario that PNM should have been required to
17 evaluate in order to present a prima facie case for abandonment.
- 18 2. The reports by Enchant Energy (Enchant) and Sargent & Lundy (S&L) on
19 which Staff witness Solomon is relying are based on a significant number
20 of overly optimistic or incorrect assumptions:
 - 21 a. That after operating at an average 70% capacity factor for almost
22 the past decade, SJGS Units 1 and 4 will run for at least 12 years at
23 an 85% to 100% capacity factor after being retrofitted for CO₂
24 capture. This assumption is overly optimistic given continuing low
25 natural gas prices, growing competition from increasingly low-cost
26 renewable resources and energy storage, and the potential for
27 declining performance due to plant aging.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 b. That capturing CO₂ at a 90% rate at commercial-scale power plants
2 for extended periods has been “proven” or “demonstrated” when,
3 in fact, neither Petra Nova nor Boundary Dam 3 has done so – in
4 spite of unsupported industry claims that they have.

5 c. That a retrofitted SJGS will capture 6 million metric tonnes of CO₂
6 a year.

7 d. That SJGS can be retrofitted at a capital cost that would be 68%
8 low than the capital cost of the Petra Nova project.

9 e. That the SJGS retrofit could be designed, planned, built and tested
10 in at least two years less time than Petra Nova and be online by
11 mid-2023.

12 f. That the cost of capturing CO₂ at SJGS will fall between \$39.15
13 and \$43.49 per metric tonne.

14 3. Mr. Solomon and Enchant and S&L have ignored entirely the substantial
15 costs and risks facing any SJGS owner(s) and/or investors that seeks to
16 continue to operate SJGS with carbon capture:

17 a. The need to pay for maintenance that the current owners of the
18 plant are deferring due to their proposal to abandon SJGS in 2022.

19 b. The likely need to pay the plant’s fixed costs for at least a year to
20 eighteen months between the shutdown of SJGS in mid- to late-
21 2022 and its restart following the retrofit, a period when the plant
22 will not be producing any revenues from the sale of electricity or
23 of captured CO₂.

24 c. The fact that it is extremely unlikely that SJGS will be a low-cost
25 generator after the retrofit and, subsequently, that any plant
26 owner(s) will lose hundreds of millions of dollars from the sale of

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 electricity. This will be because the cost of generating power at the
2 plant will be higher than the prices at which it can be sold.

3 d. That the revenues from selling captured CO₂ for enhanced oil
4 recovery will be very uncertain due to volatility in the oil markets.

5 **Q. What materials did you review and what analyses did you prepare as part of**
6 **the preparation of your testimony?**

7 A. I have reviewed the Prepared Direct Testimony of Staff Witness Solomon and the
8 documents he has included as his exhibits. In addition, I have reviewed a number
9 of presentations on the proposed carbon capture retrofit of SJGS from Enchant
10 Energy, Inc. I also have reviewed the publicly available information on the only
11 two operating power plants in the world that have been retrofitted for CO₂
12 capture: the Petra Nova project in Texas and Boundary Dam 3 in Saskatchewan,
13 Canada. Finally, my recent work has included investigating natural gas and
14 energy market prices in the Southwest and the development of renewable
15 resources and energy storage in the Mountain and Pacific states.

16 I also have analyzed the feasibility of continuing to operate SJGS after the plant is
17 retrofitted using a range of more reasonable capacity factors, CO₂ capture rates,
18 and retrofit capital costs.

19 **Q. Did Mr. Solomon conduct his own analysis of either the technical or**
20 **economic feasibility of carbon capture at SJGS?**

21 A. No, he did not. In his testimony, Mr. Solomon relies entirely on claims made by
22 Enchant Energy, the private company that has proposed the retrofit project at
23 SJGS, as well as preliminary estimates from Sargent & Lundy (S&L).

24 **Q. Does Mr. Solomon have an opinion on whether it is economically feasible to**
25 **install and operate carbon capture technology at SJGS?**

26 A. No, apparently not. Mr. Solomon admits that he provided an opinion on only the
27 technical feasibility of carbon capture, and did not evaluate the economic

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 feasibility of carbon capture at SJGS. Exhibit DAS-2, D. Solomon Depo. Tr. at
2 61: 8-16, 61:19 to 62:10.² Furthermore, Mr. Solomon admits that he does not
3 know if it would be cheaper to run SJGS with carbon capture than the alternatives
4 that PNM has put forward to abandon and replace SJGS. *Id.* at 62:21 to 63:2.
5 And Mr. Solomon has no evidence that it would be cost-effective to recover the
6 capital costs of carbon capture technology at SJGS over 12 years, as Enchant has
7 proposed to do. *Id.* at 96: 11-16.

8 **Q. What is the relevance of the claims made by Enchant and S&L to the issue of**
9 **whether it would be feasible for PNM to operate SJGS with carbon capture?**

10 A. Mr. Solomon argues that PNM should have analyzed continuing to operate to
11 SJGS with carbon capture, because that is allegedly a “feasible” scenario. Mr.
12 Solomon’s primary support for his claim that carbon capture is feasible at SJGS
13 are the statements made by Enchant and S&L. By showing that Enchant’s and
14 S&L’s claims are inaccurate, I will show that there is no evidence that it is
15 economically or financially feasible for anyone, including PNM, to continue to
16 operate SJGS with carbon capture technology.

17 **II. It is Extremely Unrealistic to Assume that a Retrofitted SJGS**
18 **Would Capture 6 Million Metric Tonnes of CO₂ Per Year.**

19 **Q. What factors determine how much carbon dioxide (CO₂) a coal-fired**
20 **generator like SJGS will capture in future years?**

21 A. Quite simply, the amount of CO₂ captured is a function of how much CO₂ a coal-
22 fired generator produces and the efficiency with which the carbon dioxide (CO₂ or
23 carbon) capture system actually captures CO₂ emissions.

24 The first factor, how much CO₂ the plant generates is, in turn, largely dependent
25 on how much it operates. The term capacity factor reflects how much power a
26 plant produces in a given period, say a month or a year, versus how much it would

² Mr. Solomon’s deposition was taken on November 13, 2019.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 have generated if it had operated at 100% power for all of the hours of the period.
2 The higher the capacity factor, the more power is generated by the plant.
3 Conversely, the lower the capacity factor, the lower the amount of power
4 generated by the plant. Similarly, the amount of CO₂ produced by a coal plant
5 goes up as its capacity factor increases.

6 Mr. Solomon's testimony that a retrofitted San Juan will capture 6 million tonnes
7 of CO₂ annually is based on two key assumptions.³ First, that San Juan Units 1
8 and 4 will operate at an average 85% to 100% capacity factor each year, thereby
9 producing large amounts of CO₂, and second, that the plant's retrofitted CCS
10 equipment will be able to capture 90% of the CO₂ produced. As I will
11 demonstrate in this testimony, neither of these assumptions is reasonable.

12 **A. A Retrofitted SJGS Cannot Be Expected to Operate at an 85% to**
13 **100% Annual Capacity Factor for An Extended Number of Years.**

14
15 **Q. Enchant and S&L evaluate the feasibility of their proposed retrofit of SJGS**
16 **for CO₂ capture using a capacity factor range of 85% to 100%.⁴ Is it**
17 **reasonable to expect that SJGS would operate at a 100% capacity factor for**
18 **a period of 12 years after being retrofitted for CO₂ capture?**

19 **A.** No. It is simply fantasy to believe that any commercial scale power plant will
20 operate at full power in every hour of the year for an extended period of time, let
21 alone for twelve years. I have not seen any evidence that any coal-fired generator
22 similar in size to SJGS Units 1 or 4 has operated at a 100% capacity factor for
23 such a period of years.

24

³ Prepared Direct Testimony of Dhiraj Solomon, at page 15, lines 10-11.

⁴ *Enchant Energy San Juan Generating Station – Units 1 & 4 – CO₂ Capture Pre-Feasibility Study*, July 8, 2019, at pages 5-4 and Appendix E, . available at https://www.enchantenergy.com/wp-content/uploads/2019/07/Enchant-Energy_SJGS-CO2-Pre-feasibility-Study_FINAL-Rev-0-7-8.pdf.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 **Q. Did Enchant and/or S&L conduct any SJGS plant-specific analysis or**
2 **modeling to evaluate at what capacity factor SJGS can be expected to**
3 **operate in future years?**

4 A. No, not that I've seen.

5 **Q. What then do you believe is the basis for the 85% low-end of the capacity**
6 **factor range at which Enchant and S&L claim SJGS will operate?**

7 A. At best, they used the 85% coal plant capacity factor that has been used in some
8 generic federal studies of carbon capture.⁵ At worst, they chose an assumed
9 capacity factor that gave them the result they needed to show that the project
10 might be economically viable -- that is, that SJGS would capture on the order of 6
11 million metric tonnes per year. Either way, neither SJGS Unit 1 or Unit 4 have
12 operated at an 85% capacity over the long-term or in recent years.

13 **Q. At what capacity factors have SJGS Units 1 and 4 operated in recent years?**

14 A. As shown in Figure 1, below, the two units achieved an average 70% capacity
15 factor between January 1, 2010 and August 31, 2019, which clearly is far below
16 the 85% average capacity factor that Enchant and S&L claim the plant will
17 achieve starting in 2023, after being retrofitted for CO₂ capture.

⁵ For example, see *Cost and Performance Baseline for Fossil Energy Plants Supplement: Sensitivity to CO₂ Capture Rate in Coal-Fired Power Plants*, U.S. DOE, National Energy Technology Laboratory (June 22, 2015), available at https://www.netl.doe.gov/projects/files/SupplementSensitivitytoCO2CaptureRateinCoalFiredPowerPlants_062215.pdf.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

Figure 1: Average SJGS Unit 1 and 4 Capacity Factors Since 2010 vs. Assumed Enchant and S&L 85% Capacity Factor




Figure Sources: SJGS data from EIA Form 923, downloaded from S&P Global Market Intelligence on November 1, 2019. Enchant and S&L assumed capacity factor is from Staff Witness Solomon's Exhibit DS-3.


Figure 1 also shows that the overall performance of SJGS Units 1 and 4 actually declined after Units 2 and 4 were retired at the end of 2017, achieving only a 62% capacity factor in the twenty months between January 2018 and August 2019.

Q. Have SJGS Units 1 and 4 achieved an 85% capacity factor in any year since 2010?

A. As shown in Figure 2 below, SJGS Units 1 and 4 did achieve 85% capacity factors in 2010 and 2011, respectively, but have failed to reach that level in any subsequent year.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

Figure 2: Annual SJGS Unit 1 and 4 Capacity Factors Since 2010 vs. Assumed Enchant and S&L 85% Capacity Factor



Sources: SJGS data from EIA Form 923, downloaded from S&P Global Market Intelligence on November 1, 2019.

Only Unit 4 achieved a capacity factor above 80% after 2011, and that was an 81% capacity factor for only the single year of 2017.


Q. What does PNM project for SJGS's future operating performance if Units 1 and 4 are not retired in 2022?

A. PNM's recent modeling of continued SJGS operation forecasts that Units 1 and 4 will achieve an average 47% capacity factor between 2023 and 2035, with the highest annual capacity factors for the units being only 53%.⁶

⁶ See the Output Reports provided in PNM's Response to Discovery Request NEE 1-72.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

Figure 3: PNM Modeling Results vs. Enchant and S&L's Assumed 85% Capacity Factor for SJGS Units 1 and 4



Sources: Scenario 1 Output Reports provided in PNM's Expedited Response to NEE Interrogatory 1-72 in Case No. 19-00018-UT.

Q. Did PNM's modeling of continued operation of SJGS reflect the plant's retrofit with carbon capture?

A. No.

Q. Is it reasonable to expect that SJGS's future capacity factors will be substantially lower than 85% if the plant continues to operate after 2022?

A. Yes. There are a number of factors which, I believe, are likely to lead to a significant decline in SJGS operating performance if the new owner(s) attempt to continue to run the plant after retrofitting it for CO₂ capture. These include:

1. Continued low natural gas prices.
2. Growing competition from renewable resources, including energy storage.
3. Increasing integration of the western power grid.
4. The impact of plant aging.
5. The impact of reduced spending on maintenance by the current owners.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel


6. The fact that SJGS will be a more complicated plant to operate.

I will explain each of these factors in greater detail below.

Q. What are the market's expectations for future natural gas prices at trading hubs in the Southwest?

A. Similar to what has happened throughout the U.S., natural gas prices at trading hubs in the Southwest have declined significantly since 2008 and are expected to remain low for the foreseeable future, as can be seen in Figure 4, below.

Figure 4: Past and Forward Natural Gas Prices in the Southwestern U.S.



Source: Past Natural Gas Prices downloaded from S&P Global Market Intelligence on October 31, 2019. Forward prices from OTC Global Holdings, also downloaded from S&P Global Market Intelligence on October 31, 2019.


Continued low gas prices will undermine the financial viability of projects like retrofitting San Juan with CCS by reducing fuel costs for the natural gas plants with which San Juan competes. This, in turn, will lead to (a) lower energy market prices and (b) increased generation at gas-fired plants, thereby displacing generation that otherwise would be produced at San Juan.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 **Q.** **Has generation from wind and solar resources grown significantly in the**
2 **western U.S. in recent years?**

3 **A.** Yes. As prices have declined dramatically, the generation from solar more than
4 doubled just between 2012 and 2018.

5 **Figure 5: Rapid Growth in Wind and Solar Generation in the Western United**
6 **States, 2012 to 2018**



7
8 Source: EIA Electric Power Monthly.

9 And significantly more renewable resources are likely to be added in the western
10 U.S. in coming years. For example, California now mandates that 33% of
11 electricity sales in 2020 and 60% of sales in 2030 be from renewable resources.⁷
12 In addition, utilities in other states in the region also are planning to add
13 substantial amounts of new wind and solar resources, as are independent power
14 producers. Many of these resources will compete with San Juan and displace
15 generation that the plant would otherwise produce.

⁷ Stats. 2018, Ch. 312, Sec. 2. (SB 100) (effective Jan. 1, 2019); Cal. Pub. Util. Code § 399.11.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 **Q. What has happened to wind and solar PPA prices in recent years?**

2 **A.** Wind and utility-scale solar PPA prices have declined sharply in recent years.
3 From 2009 to 2016, average levelized wind PPA prices fell from \$70 per MWh to
4 about \$20. Average levelized solar PPA prices declined by 75% from 2009 to
5 2016 and were about \$35 per MWh for new projects in 2016.

6 Solar and wind PPA prices have dropped further in 2017 and 2018. In December
7 2017, Xcel Energy reported that a power-generation solicitation in Colorado drew
8 bids for renewable power that were “incredible.”⁸ The median bid for 17,380 MW
9 of wind projects received by Xcel Energy was \$18.10 per MWh; for 5,097 MW of
10 wind-plus-battery storage projects, the median bid was \$21 per MWh; the median
11 bid for 13,345 MW of solar projects was \$29.50 per MWh; for 10,813 MW of
12 solar-plus-storage, the median bid was \$36 per MWh.⁹ And Nevada Energy
13 reported receiving “staggering” prices in more than 100 bids for biomass,
14 geothermal, solar, wind and battery storage projects in response to a request for
15 proposals, with battery-backed solar projects priced below \$30 per MWh.¹⁰

16 **Q. How will increasing regional integration of electricity markets hurt future**
17 **SJGS operating performance?**

18 **A.** Efforts have been under way in recent years to better integrate western electric
19 markets. For example, a western Energy Imbalance Market (EIM) has been
20 launched. The EIM is “a real-time wholesale energy trading market that enables
21 participants anywhere in the West to buy and sell energy when needed.”¹¹ One of

⁸ <https://www.utilitydive.com/news/xcel-solicitation-returns-incredible-renewable-energy-storage-bids/514287/>.

⁹ Public Service Company of Colorado, 2016 Electric Resource Plan 2017, All Source Solicitation 30-Day Report (Public Version), CPUC Proceeding No. 16A-0396E (Dec. 28, 2017), *available at* https://cdn.arstechnica.net/wp-content/uploads/2018/01/Proceeding-No.-16A-0396E_PUBLIC-30-Day-Report_FINAL_CORRECTED-REDACTION.pdf.

¹⁰ G. Hering, ‘Staggering’ prices drive NV Energy’s 100% renewables bid amid ballot wrangle, S&P Global Market Intel. (Apr. 13, 2018), *available at* <https://www.spglobal.com/marketintelligence/en/news-insights/trending/xrl7pjatkohn-o95bsv1pq2>

¹¹ <https://www.westerneim.com/pages/default.aspx>.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 its goals is to find and deliver the lowest cost energy to consumers.¹² Another goal
2 is that by optimizing resources from a larger and more diverse pool, it is able to
3 better facilitate the integration of renewable energy that otherwise may be
4 curtailed at certain times of the day. There are currently nine members in the EIM,
5 including the California Independent System Operator (CAISO), and APS and
6 NV Energy in the Southwest. Salt River Project, PNM, and Tucson Electric
7 Power are scheduled to join by 2022, meaning that participants representing 77
8 percent of the Western Electricity Coordinating Council's total load will be active
9 in the EIM.

10 The growth of the EIM amplifies the risk to San Juan from low-cost renewable
11 resources in California and the rest of the West, as it will mean increased
12 exposure to renewables prices that may be lower than San Juan's marginal costs.

13 **Q. What is the significance of plant aging on the expected future operating**
14 **performance of SJGS Units 1 and 4?**

15 A. San Juan Unit 1 is currently 43 years old. Unit 4 is 37. By 2023, the Units will be
16 47 and 41 years old, respectively. By 2030, they will be 54 and 48 years old. This
17 is important because older plants, on average, tend to cost more to operate and
18 maintain and are less reliable according to analyses by the U.S. Department of
19 Energy's Argonne National Laboratory and the National Energy Technology
20 Laboratory, which have found that coal plant heat rates increase with plant age,
21 while plant availability declines.¹³ Heat rate is a measure of a power plant's
22 efficiency in generating electricity; a higher heat rate means that a plant is less
23 efficient. And, in general power plants tend to become less efficient as they age.
24 Plant availability measures the percentage of possible operating hours in which a

¹² CAISO, Press Release (Oct. 30, 2019), *available at*
http://www.caiso.com/Documents/WesternEIMBenefitsReach801_07MillionSinceLaunchIn2014.pdf.

¹³ See, e.g., U.S. Dep't of Energy, Staff Report to the Secretary on Electricity Markets and Reliability *at* 155 (Aug. 2017), *available at*
https://www.energy.gov/sites/prod/files/2017/08/f36/Staff%20Report%20on%20Electricity%20Markets%20and%20Reliability_0.pdf.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 plant was actually available to generate power, and plants tend to become less
2 available to generate power as they age, in part because they tend to experience
3 more unanticipated problems and unplanned outages.

4 At the same time, older plants tend to cost more to maintain, as equipment and
5 components degrade or fail and must be repaired or replaced. These factors must
6 be considered by potential plant owners and investors as they decide to participate
7 in retrofit projects at aging coal plants such as SJGS.

8 **Q. Are there any other factors that could lead to lower SJGS capacity factors in**
9 **the future after the plant is retrofitted for carbon capture?**

10 A. Yes. For example, I understand that in Docket No. 16-00276, PNM was pressed
11 to avoid and defer capital spending for SJGS through 2022 that was not required
12 for regulatory compliance or that were not needed for health and safety. In
13 response to Sierra Club discovery in that case, PNM stated it was cancelling two
14 projects it had previously planned: San Juan Common C&D Coal Reclaim System
15 (ID# 76617317) and San Juan Common Auxiliary Boiler (ID# 76616917).¹⁴

16 The actions of PNM and the other co-owners (except for Farmington) are
17 consistent with common sense and what I have seen other utilities do: they stop
18 spending money on major maintenance projects in the years leading up to an
19 expected retirement date. For example, at the Navajo Generating Station, by May
20 2017, the Salt River Project (SRP) and the other Navajo Generating Station
21 owners already had started to plan to reduce their maintenance spending to
22 prepare for the plant's announced retirement in December 2019. SRP has said that
23 the amount of deferred maintenance for all three units at NGS was about \$132
24 million, or \$44 million per unit.¹⁵ Although the precise cost of such deferred
25 maintenance at SJGS is unknown and would be specific to SJGS, this suggests

¹⁴ See PNM's Response to Discovery Request SC 2-5 in Docket No. 16-00276.

¹⁵ Arizona Republic, "10 Obstacles to keeping the Navajo coal plant open," May 22, 2017, *available at* <https://www.azcentral.com/story/money/business/energy/2017/05/22/arizona-10-challenges-keeping-navajo-generating-station-open/332911001/>.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 that any owner(s) of SJGS who would try to continue to operate SJGS past 2022
2 would have to pay a significant amount for maintenance work that previously
3 would have been deferred by the current owners.

4 **Q. What would be the risk if the owner(s) of SJGS tried to continue operating**
5 **SJGS past 2022 but failed to pay for this deferred maintenance?**

6 A. There would be a heightened risk of future equipment degradation and
7 breakdowns, and more frequent and longer plant outages and deratings. This
8 would both make it more expensive to operate and maintain the plant in the future
9 and more difficult to achieve the higher capacity factors that will be needed to
10 obtain the tax credits promised to investors.

11 **Q. What is your conclusion about the likely operating performance of SJGS if**
12 **the plant were retrofitted for carbon capture?**

13 A. In their pre-feasibility analyses, Enchant and S&L assume that the operating
14 performance of SJGS, which has averaged a 70% capacity factor over the past
15 decade, will improve dramatically after being retrofit for carbon capture, and will
16 average 85% or higher annual capacity factors for an entire twelve year period.
17 This assumption is very unrealistic. It is far more likely that SJGS's post-retrofit
18 average annual capacity factors would fall somewhere in the range between a
19 70% high end (reflecting its recent operating performance) and a low end of the
20 47% average capacity factor forecast in PNM's modeling analyses.

21 **Q. Is it possible that the plant's operating performance could be even worse**
22 **than this?**

23 A. Yes. As a result of the factors I have discussed above, PNM (or Enchant's
24 investors and the new SJGS owner) would be exposed to the not-insignificant risk
25 that the plant's operating performance could be worse than an average 47%
26 capacity factor.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 **Q. How many existing coal-fired generators actually have achieved 85%**
2 **capacity factors in recent years?**

3 A. It has been extremely rare in recent years that a coal-fired generator has achieved
4 an 85% capacity factor in a single year, let alone over several years. In fact, only
5 thirteen of the 390 coal-fired units in operation in 2018, or barely three percent,
6 achieved 85% or higher capacity factors in 2018. Fifty seven units, or four times
7 as many, failed to achieve even a 30% capacity factor in the same year.¹⁶

8 Similarly, only four of the 390 coal-fired generators operating in 2018, or just one
9 percent, achieved 85% or higher average capacity factors during the four-year
10 period 2015 to 2018. Only 10 units had average capacity factors of 80% or higher.
11 At the same time, 36 units had average capacity factors of 30% or lower during
12 the same period.

13 **B. 90% CO₂ Capture Has Not Been Proven.**

14 **Q. Staff witness Solomon testified that both the Petra Nova project at NRG's**
15 **W.A. Parish Unit 8 plant outside Houston, TX, and Boundary Dam Unit 3**
16 **located in Saskatchewan, Canada, "operate at 90% CO₂ capture**
17 **efficiency."¹⁷ Is this accurate?**

18 A. No. Publicly available evidence shows that neither plant captures anywhere near
19 90% of the CO₂ they produce, contrary to claims by Enchant and S&L that these
20 plants have achieved 90% CO₂ capture rates.¹⁸

¹⁶ Source: EIA Form 923 data downloaded from S&P Global Market Intelligence on November 5, 2019.

¹⁷ Prefiled Direct Testimony of Dhiraj Solomon, PE, at page 13, lines 15-17.

¹⁸ Enchant Energy Corporation, Response to Institute for Energy Economics and Financial Analysis report at 2, available at <https://www.enchantenergy.com/wp-content/uploads/2019/07/Enchant-Energy-Corporation-response-to-Institute-for-Energy-Economics-and-Financial-Analysis-IEEFA-report-dated-July-2019.pdf>.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

Q. What is the basis for your conclusion that Petra Nova is not capturing 90% of the CO₂ it produces?

A. Petra Nova *intended* to capture “at least” 90% of the CO₂ from a 240 MW equivalent slip stream from the flue gas emitted by the 654 MW coal-fired W.A. Parish Unit 8. This has been variously translated into an expectation that Petra Nova would capture somewhere between 1.54 and 1.6 million tons of CO₂ (that is, approximately 1.4 million metric tonnes) or about 33% of the total emissions from Unit 8, each year.¹⁹

Despite the Petra Nova project’s goal of capturing 90% of CO₂ emissions, I could not find any evidence that Petra Nova actually was capturing that much CO₂ or that the technology had been proven to be that effective. Thus, I examined Petra Nova’s actual performance in three separate analyses using publicly available information.

First, I investigated whether Petra Nova actually was capturing between 1.54 and 1.6 million tons of CO₂ each year. Unfortunately, NRG, the operator and co-owner of the plant, has not regularly issued detailed reports on the amounts of CO₂ captured at Petra Nova. However, representatives from the company and from the U.S. DOE (which supplied \$190 million of the \$1 billion cost of the project) spoke at the IEA Clean Coal Conference held in Houston and revealed that Petra Nova had captured (1) 2.4 million tons of CO₂ between its start of operations in January 2017 and December 2018 and (2) almost 3.0 million tons through May 2019.²⁰


¹⁹ W.A. Parish Post-Combustion CO₂ Capture and Sequestration Project, Topical Report at 3, *available at* <https://www.osti.gov/biblio/1344080-parish-post-combustion-co2-capture-sequestration-project-final-public-design-report>; EIA, Today in Energy, Petra Nova is one of two carbon capture and sequestration power plants in the world, (Oct. 31, 2017), *available at* <https://www.eia.gov/todayinenergy/detail.php?id=33552>; National Energy Technology Laboratory, W.A. Parish Post-Combustion CO₂ Capture and Sequestration Project (Sept. 2012), *available at* https://www.netl.doe.gov/sites/default/files/environmental-policy/deis-sept/EIS-0473D_Summary.pdf.

²⁰ *PETRA NOVA Carbon Capture, June 2019, IEA Clean Coal Conference*, Greg Kennedy, NRG’s Senior Project Manager at Petra Nova and [Status Update of U.S. Department of Energy Major Fossil Energy](#)

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 As shown in Figure 6, below, these amounts of captured CO₂ are significantly
2 below what would be expected if Petra Nova actually had been capturing 90% of
3 the CO₂ it produced.

4 **Figure 6: Actual vs. Target Amounts of CO₂ Captured at Petra Nova**



5
6 *Source: STC analysis.*

7 The actual amounts of CO₂ captured at Petra Nova translate into a capture rate of
8 69% thru December and 71% from January 2017 thru May 2019.


9 **Q. Is it possible that Petra Nova actually was capturing 90% of the CO₂ in the**
10 **240 MW slipstream even though it was capturing less CO₂ than projected? In**
11 **other words, is there any evidence that W.A. Parish Unit 8 was producing**
12 **less CO₂ after January 2017 because the unit was operating less?**

13 **A.** No. Figure 7, below, shows that Parish Unit 8 actually had a slightly higher
14 capacity factor after January 2017 than it did in the previous two years.

[*Carbon Capture & Geologic Storage Projects in Operation and Lessons Learned*](#), also presented at the same IEA Clean Coal Conference.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

Figure 7: W.A. Parish Unit 8 Capacity Factors



Sources: EIA Form 923 data, downloaded from S&P Global Market Intelligence.


Q. Please describe the second analysis you made to determine if Petra Nova is actually achieving a 90% CO₂ capture rate.

A. As I noted earlier, the U.S. Energy Information Administration (EIA) forecasted that if Petra Nova captured 90% of the CO₂ emitted from the 240 MW equivalent flue gas slipstream, that would be capturing about 33% of the total emissions from Parish Unit 8. To see whether this was happening, I compared the CO₂ intensity (measured as tons of CO₂ per MWh of generation) of the emissions from Unit 8 for the period January 2017 through August 2019 (the most recent data from the EPA's Continuous Emissions Monitoring System [CEMS] database that was available) with the emissions during the two years before Petra Nova went into operation.

Figure 8, below, shows that Unit 8's actual CO₂ intensity is higher than it would be if Petra Nova actually were capturing 90% of the CO₂ in the 240 MW slipstream.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

Figure 8: Projected and Actual W.A. Parish Unit 8 CO₂ Intensity



Source: Analysis of W.A. Parish Unit 8 CO₂ Emissions and Gross Generation from EPA CEMS database.


The third column, representing the plant's actual performance, shows a CO₂ intensity that would be expected if Petra Nova operated at a 69% capture efficiency through August 2019, which confirms the results of our first analysis.

Q. Please describe your third analysis of Petra Nova's CO₂ capture rate.

A. In the last analysis, I calculated what Parish Unit 8's total CO₂ emissions during the period January 2017 through August 2019 would have been under a range of alternative capture rates for the 36.7% of the flue gas stream that could potentially be captured. The results are presented in Figure 9, below. These results confirm that Petra Nova has achieved about a 70% CO₂ capture rate since the project went into operation in January 2017, not the 90% capture rate that Mr. Solomon and others claim.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

Figure 9: Total W.A. Parish Unit 8 CO₂ Emissions Under a Range of Potential Capture Rates



Source: Analysis of W.A. Parish Unit 8 CO₂ Emissions from EPA CEMS database.

Q. Do you have any other comments on Petra Nova's CO₂ capture rate?

A. Yes. Unlike the proposed retrofit of SJGS, the power to run the CO₂ capture equipment at Petra Nova is provided by a dedicated natural gas-fired combustion turbine. If the CO₂ emissions from this CT were included in the analysis, Petra Nova's net capture rate would be substantially lower, perhaps as low as 60% or even 50%.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 **Q. Is it correct that similar to Petra Nova, the Boundary Dam power plant in**
2 **Canada also is not capturing 90% of the CO₂ it produces?**

3 A. Yes. As I mentioned earlier, the Petra Nova and Boundary Dam projects are the
4 only two CO₂ projects in the world operating at power plants.²¹ Like Petra Nova,
5 the Boundary Dam project has not been capturing 90% of the CO₂ it produces.


6 **Q. What is the basis for your conclusion that Boundary Dam also is not**
7 **capturing 90% of the CO₂ it produces?**

8 A. The carbon capture system at the 110 MW Boundary Dam Unit 3 in
9 Saskatchewan, Canada, began operating in October 2014. Although the system
10 was designed to capture 1 million tonnes a year reflecting a 90% capture rate, it
11 has failed to achieve this goal in the 45 months between October 2014 and July
12 2019.

²¹ The proposed SJGS Carbon Capture project would be 3.8 times larger than Petra Nova. Mr. Solomon acknowledges that no power plant in the world as large as SJGS has installed carbon capture technology. Exhibit DAS-2, D. Solomon Depo. Tr. at 83: 15-24.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

Figure 10: Boundary Dam Unit 3 Target vs. Actual CO₂ Capture in Tonnes



Source: SaskPower, BD3 Status Updates.²²

In fact, the plant's carbon capture system only operated at its design capacity of 3200 tonnes per day on 3 days through early 2018.²³


Consequently, Boundary Dam Unit 3 has failed to achieve a 90% carbon capture rate in any significant period since the plant was retrofitted.

²² The most recent update is available at <https://www.saskpower.com/about-us/our-company/blog/bd3-status-update-october-2019>. Previous updates containing information on CO₂ captured in prior years are available at SaskPower's blog.

²³ *Boundary Dam 3: Upgrades, updates and performance optimization of the world's first fully integrated CCS plant on coal*, presented by Corwin Bruce from the International CCS Knowledge Centre at the 2019 Clean Coal Technologies Conference on June 5, 2019. The International CCS Knowledge Centre is 50% owned by SaskPower, the owner of Boundary Dam Unit 3.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

Figure 11: Boundary Dam Unit 3 Targeted vs. Actual CO₂ Capture Rates



Source: Analysis using CO₂ capture performance data in Boundary Dam 3 Status Reports on SaskPower website.

Q. Is it possible that some of Boundary Dam's failure to capture 90% of the CO₂ it produces is due to operating issues unrelated to the CO₂ capture equipment?

A. Yes. Boundary Dam 3 has had significant issues with the CO₂ capture equipment that have adversely impacted its ability to capture emissions and led to increased maintenance costs and plant downtime. For example, the carbon capture portion of the plant worked only about 40% of the time in much of 2014 and 2015 with the CCS plant being shut down for a nearly two-month maintenance outage in the fall of 2015.²⁴ And the plant was shut down for 96 days in 2017 to complete projects designed to improve the reliability of the CCS plant.²⁵ SaskPower has said that the cost of fixing Boundary Dam 3's carbon capture flaws cost CAN\$32

²⁴ [Carbon Capture and Sequestration @ MIT](#) and [SaskPower's 2015-2016 Annual Report](#) at 59.

²⁵ [SaskPower's 2017-2018 Annual Report](#) at 36.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 million in the years 2015 and 2016 and estimated that it was going to cost another
2 CAN\$15 million in 2017.²⁶

3 It is true that Boundary Dam 3 also has experienced some plant outages that were
4 unrelated to its CO₂ capture system. However, these outages account for only a
5 fraction of the plant's failure to come anywhere near an overall 90% CO₂ capture
6 rate.

7 For example, SaskPower has claimed that 2018 was a strong year for carbon
8 capture and storage at Boundary Dam Station, saying that the plant would have
9 captured more than 625,996 tonnes of CO₂ in the year if it had not be shut down
10 for 84 days due to a strong storm and massive power outage.²⁷ However, in the
11 unlikely event that Boundary Dam had actually captured CO₂ at it maximum daily
12 rate of 3,200 tonnes (a goal it achieved for just 3 days in its first 40 months after
13 being retrofitted) for all of the 84 days of this outage, the plant's CO₂ capture rate
14 still would have been only 80%, not 90%.

15 **Q. Did SaskPower have to pay any contract penalties because it was unable to**
16 **provide the amounts of CO₂ it has committed to providing to buyers?**

17 A. Yes. SaskPower has reported that in 2014, it paid \$12 million in penalties to
18 Cenovus Energy for failing to deliver sufficient quantities of carbon dioxide from
19 Boundary Dam 3.²⁸ In 2015, SaskPower paid \$7.3 million to Cenovus for failing
20 to deliver the volume of CO₂ it had contractually committed to provide.²⁹

²⁶ CBC News, "SaskPower looking for help to fix 'high cost' Boundary Dam carbon capture flaw," May 28, 2018, available at <https://www.cbc.ca/news/canada/saskatchewan/saskpower-looking-for-help-to-fix-high-cost-boundary-dam-carbon-capture-flaw-1.4680993>.

²⁷ SaskPower, Press Release, "Strong Year for Carbon Capture and Storage at Boundary Dam Power Station," January 22, 2019, available at <https://www.saskpower.com/about-us/media-information/news-releases/Strong-year-for-carbon-capture-and-storage-at-Boundary-Dam-Power-Station>.

²⁸ The Energy Mix, "Saskatchewan Pays \$12 Million Penalty for Slow Production at CCS Plant," Nov. 4, 2015, available at <https://theenergymix.com/2015/11/04/saskatchewan-pays-12-million-penalty-for-slow-production-at-ccs-plant/>.

²⁹ CBC News, "SaskPower CEO says \$20M worth of carbon capture penalties are in the past," July 14, 2016, available at <https://www.cbc.ca/news/canada/saskatchewan/saskpower-carbon-capture-penalties-20m-in-past-1.3679405>.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 **Q. Has SaskPower’s failure to deliver the contracted amounts of CO₂ had any**
2 **long-term impacts on the revenues it gets from selling the CO₂ captured at**
3 **Boundary Dam 3?**

4 A. Yes. It has been reported that in June 2016, the contract for supplying CO₂ from
5 Boundary Dam Unit 3 was renegotiated, reducing the expected annual revenues
6 over the life of the plant by about a third.³⁰

7 **Q. Have you seen any evidence that Mr. Solomon or Enchant and S&L have**
8 **analyzed the impact that post-retrofit plant outages, needed upgrades, or**
9 **higher CO₂ capture O&M costs would have on the financial viability of the**
10 **retrofit they are proposing for SJGS?**

11 A. No.

12 **Q. Has the underperformance of Boundary Dam 3’s CO₂ capture system**
13 **affected SaskPower’s decisions concerning retrofitting other units for CO₂**
14 **capture?**

15 A. Yes. “After careful evaluation, SaskPower has made the decision to not retrofit
16 Boundary Dam Power Station Units #4 and #5 with CCS technology.”³¹

17 **Q. Based on your testimony so far, should a retrofitted SJGS be expected to**
18 **capture substantially less than six million tonnes of CO₂ per year, on**
19 **average?**

20 A. Yes. This conclusion is based on (1) the fact that no commercial-scale power
21 plant has achieved 90% (or even 80%) CO₂ capture over any significant period of
22 time and (2) SJGS’s actual operating performance and the results of PNM’s
23 computer modelling showing lower capacity factors for the plant in future years.

³⁰ The Global Warming Policy Foundation, The Bottomless Pit: The Economics of Carbon Capture and Storage at 55 (2017), available at <https://www.thegwpf.org/content/uploads/2017/06/CCS-Report.pdf>.


³¹ SaskPower Annual Report 2018-2019 at 39, available at <https://www.saskpower.com/about-us/Our-Company/Current-Reports>.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 **Q. Realistically, how much CO₂ do you think the carbon capture system at**
2 **SJGS would capture each year, on average?**

3 A. Based on the evidence I have reviewed, and the analyses I have discussed earlier,
4 I believe a retrofitted SJGS should be expected to capture no more than 2.2 to 4.4
5 million tonnes of CO₂ per year. And even that assumes that there are no
6 significant issues encountered in scaling up the capture technology from the 240
7 MW-equivalent Petra Nova project to the proposed 914 MW SJGS project.

8 **Figure 12: Tonnes of Captured Carbon that Can Be Expected from a**
9 **Retrofitted SJGS**



Source: Analysis based on methodology from Appendix E in S&L July 8, 2019 Pre-Feasibility Study.

13 **Q. Why does the amount of CO₂ captured by SJGS matter to the financial**
14 **feasibility of the proposed carbon capture project?**

15 A. The amount of CO₂ that is captured is critical to the project's financial feasibility
16 because it affects both the tax credits for which the project would be eligible and
17 the revenue that would be generated from selling the captured CO₂.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 **Q. What is the significance of projecting that SJGS would only be able to**
2 **capture 2.2 to 4.4 million metric tonnes a year instead of the 6.0 million**
3 **tonnes that Enchant claims?**

4 A. Capturing less CO₂ will mean that SJGS will generate less revenue from the sale
5 of the CO₂ for enhanced oil recovery. Similarly, capturing less CO₂ will mean that
6 the project will be eligible for far fewer 45Q tax credits. This, in turn, will mean
7 that additional funds will have to be borrowed to pay for the retrofitting of SJGS.
8 This will raise both the total capital cost of the retrofit and the cost per metric
9 tonne of capturing CO₂, as I will describe in detail later in this testimony.

10 **Q. Have you evaluated how much additional funding would be required?**

11 A. Yes. Because of the significant uncertainty associated with the future performance
12 of SJGS and the cost of retrofitting CO₂ capture, I have looked at sixteen
13 scenarios that cover a range of reasonable capacity factors, CO₂ capture rates and
14 capital costs. These include:

- 15 • Two sets of annual capacity factors with a high set of 70% and a low set
16 which averages 47%.
- 17 • CO₂ capture rates of 80%, 70% and 60%.
- 18 • Capital costs in 2023 dollars that range from a low capital cost of \$1.40
19 billion (representing the 2019 S&L estimated cost); a mid-capital cost of
20 \$2.21 billion (representing 50% of the cost of building Petra Nova); and a
21 high capital cost of \$3.31 billion (representing 75% of the actual Petra
22 Nova cost.

23 **Q. What discount rate have you used in this analysis to calculate the present**
24 **value of the 45Q tax credits that investors in the SJGS retrofit could expect**
25 **to receive?**

26 A. Based on the recommendation of David Posner, who is submitting separate
27 testimony, I have used a 15% discount rate.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 **Q. What is the 45Q tax credit?**

2 A. As witness David Posner describes in greater detail in his testimony, the 45Q tax
3 credit refers to federal tax credits available to certain carbon capture and
4 sequestration projects.

5 **Q. What capital costs do Enchant and S&L estimate for the CO₂ capture**
6 **retrofit project at SJGS?**

7 A. S&L estimates a capital cost of approximate \$1.295 billion, in 2019 dollars, to
8 retrofit SJGS with CO₂ capture technology.³² This is \$1,417 per kW.

9 **Q. What are the results of your analysis?**

10 A. Table 1, below, shows the percentages of the capital cost of retrofitting SJGS that
11 can be expected to be obtained through tax equity financing from 45Q credits and
12 the percentage of the estimated capital costs that would have to be funded from
13 other sources in each of the scenarios I have examined.

³² *Appendix E in S&L's July 8, 2019 CO₂ Capture Pre-Feasibility Study, available at*
https://www.enchantenergy.com/wp-content/uploads/2019/07/Enchant-Energy_SJGS-CO2-Pre-feasibility-Study_FINAL-Rev-0-7-8.pdf.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

Table 1
SJGS Retrofit Financing

		Percentage of Estimated Capital Cost that Could Be Funded through 45Q Credits	Percentage of Estimated Capital Cost that Would Have to be Obtained Through Non-45Q Funding
	Scenario Assumptions		
Corrected Enchant & S&L Proposal	\$1.40 Billion Capital Cost, 85% CF & 90% CO ₂ Capture Rate	81%	19%
Scenario 1	\$1.40 Billion Capital Cost, 70% CF & 80% CO ₂ Capture Rate	59%	41%
Scenario 2	\$1.40 Billion Capital Cost, 70% CF & 70% CO ₂ Capture Rate	52%	48%
Scenario 3	\$1.40 Billion Capital Cost, 70% CF & 60% CO ₂ Capture Rate	45%	55%
Scenario 4	\$2.21 Billion Capital Cost, 70% CF & 80% CO ₂ Capture Rate	38%	62%
Scenario 5	\$2.21 Billion Capital Cost, 70% CF & 70% CO ₂ Capture Rate	33%	67%
Scenario 6	\$2.21 Billion Capital Cost, 70% CF & 60% CO ₂ Capture Rate	28%	72%
Scenario 7	\$3.31 Billion Capital Cost, 70% CF & 80% CO ₂ Capture Rate	25%	75%
Scenario 8	\$3.31 Billion Capital Cost, 70% CF & 70% CO ₂ Capture Rate	22%	78%
Scenario 9	\$3.31 Billion Capital Cost, 70% CF & 60% CO ₂ Capture Rate	19%	81%
Scenario 10	\$1.40 Billion Capital Cost, 47% CF & 80% CO ₂ Capture Rate	40%	60%
Scenario 11	\$1.40 Billion Capital Cost, 47% CF & 70% CO ₂ Capture Rate	35%	65%
Scenario 12	\$1.40 Billion Capital Cost, 47% CF & 60% CO ₂ Capture Rate	30%	70%
Scenario 13	\$2.21 Billion Capital Cost, 47% CF & 80% CO ₂ Capture Rate	25%	75%
Scenario 14	\$2.21 Billion Capital Cost, 47% CF & 70% CO ₂ Capture Rate	22%	78%
Scenario 15	\$2.21 Billion Capital Cost, 47% CF & 60% CO ₂ Capture Rate	19%	81%
Scenario 16	\$3.31 Billion Capital Cost, 47% CF & 80% CO ₂ Capture Rate	17%	83%
Scenario 17	\$3.31 Billion Capital Cost, 47% CF & 70% CO ₂ Capture Rate	15%	85%
Scenario 18	\$3.31 Billion Capital Cost, 47% CF & 60% CO ₂ Capture Rate	13%	87%

Q. Why is the first row of Table 1 described as the “Corrected Enchant & S&L Proposal?”

A. Appendix E in S&L’s July 8, 2019 *CO₂ Capture Pre-Feasibility Study* lists the Total Project Cost as \$1.295 billion.³³ On page 5-3 of the same document, this cost is clearly presented as being in 2019 dollars. However, the earliest date Enchant offers for the restart of SJGS after the retrofit is mid-2023.³⁴ Therefore, I have corrected the S&L analysis by converting the estimated S&L total project cost to \$1.40 billion in 2023 dollars.

Q. What do you conclude from Table 1?

A. The S&L Base Case is completely unrealistic because the project is extremely unlikely to achieve either an 85% average annual capacity factor or a 90% CO₂ rate. In addition, as I will explain in the next section, the project’s capital cost will very likely exceed S&L’s \$1.295 billion estimate (in 2019 dollars). But even with

³³ Available at https://www.enchantenergy.com/wp-content/uploads/2019/07/Enchant-Energy_SJGS-CO2-Pre-feasibility-Study_FINAL-Rev-0-7-8.pdf.

³⁴ Enchant Energy, Carbon Capture Retrofit of San Juan Generating Station Presentation to San Juan County Community at Slide No. 12 (July 16, 2019), , available at <https://www.enchantenergy.com/wp-content/uploads/2019/07/Enchant-SJGS-Presentation-to-San-Juan-Community-July-2019.pdf>.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 these unrealistic assumptions, tax equity financing would likely be able to provide
2 only about 81% of the funds needed to retrofit SJGS with carbon capture. The
3 remaining funding would have to come from other sources.

4 In scenarios with more realistic assumptions, at least 41% of the cost of
5 retrofitting SJGS for carbon capture would have to be raised from what might be
6 even more expensive sources of financing than tax equity.

7 **III. Retrofitting SJGS for CO₂ Capture is Likely to be Much More**
8 **Expensive than Claimed in the Enchant and S&L Reports that**
9 **Mr. Solomon Relies On.**

10 **Q. Staff witness Solomon has testified that “The 2019 Sargent & Lundy report**
11 **shows that the technology has improved, capital costs have gone down and**
12 **auxiliary power and steam consumption needs are lower.”³⁵ Do you agree?**

13 A. No. Mr. Solomon is comparing the 2019 S&L **estimate** with the 2010 S&L
14 **estimate**. He is not comparing **actual** plant construction costs. Thus, the mere fact
15 that the more recent 2019 S&L report estimates a lower capital cost for
16 retrofitting SJGS for CO₂ capture does not offer any proof that the actual cost of
17 retrofitting the plant will be any lower than S&L estimated in 2010. At the same
18 time, the lower 2019 S&L capital cost estimate also provides no guarantee that the
19 actual cost of retrofitting SJGS, in fact, will not be higher than S&L estimated
20 back in 2010.

21 **Q. How do S&L’s 2010 and 2019 estimated capital costs for retrofitting SJGS**
22 **with CO₂ capture compare with the actual capital cost of the Petra Nova**
23 **project which was built in the years 2014 to 2016?**

24 A. The actual cost of building Petra Nova was \$1 billion, or \$4,200 per kW for a 240
25 MW facility.³⁶ Figure 13 below shows that this was substantially more expensive


³⁵ Prepared Direct Testimony of Dhiraj Solomon, PE, at page 14, lines 20-22.

³⁶ EIA, Today in Energy, “Petra Nova is one of two carbon capture and sequestration power plants in the world,” (Oct. 31, 2017), available at <https://www.eia.gov/todayinenergy/detail.php?id=33552>.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 than S&L estimated in both 2010 and 2019 for the cost of retrofitting SJGS.³⁷
2 This is approximately three times the cost estimate from S&L that Mr. Solomon
3 relies upon.

4 **Figure 13: Actual Petra Nova Cost vs. S&L Estimates for Retrofitting**
5 **SJGS with CO₂ Capture**



6
7 *Source: Analysis based on costs from EIA Today in Energy for October 31, 2017 and Exhibits DS-*
8 *1 and DS-2 to the Prepared Direct Testimony of Dhiraj Solomon.*

9 Figure 13 shows that the actual cost of designing and building the only existing
10 commercial-scale CO₂ capture project in the U.S. was significantly higher, on a
11 per kW basis, than S&L estimated for retrofitting SJGS in both 2010 and 2019.

³⁷ Note that the actual \$4,200 per kW cost of Petra Nova and both the 2010 S&L estimate in Figure 13 have been converted to 2019 dollars to be on a comparable basis as the 2019 S&L estimate.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

Q. What does the comparison shown in Figure 13 say about the reasonableness of the S&L 2019 cost estimate for retrofitting SJGS on which Mr. Solomon relies?

A. The theory underlying the development of new technologies, such as carbon capture at commercial scale power plants, is that, over time, lessons learned from the construction and operation of new plants will drive down the prices for building and running each successive unit.

For example, the cost of installing new utility-scale solar capacity declined by 2/3 between 2007-2009 and 2017, as a result of the lessons learned in the building and installation of 24.7 GW of new solar capacity.³⁸ Similarly, the prices of installing new wind capacity fell by 40% between 2009/2010 and 2018, as a result of the lessons learned during the installation of 56 GW of new wind capacity.³⁹

However, carbon capture technology today is not like solar and wind technology. Solar and wind prices declined because of many factors, including significant research and development, robust competition among suppliers, and an extremely large number of commercial projects around the world. By contrast, there are only two carbon capture projects at power plants in the entire world. Unlike the situation for solar and wind technologies, there are not a large number of projects either operating, under construction, or in the pipeline that could be expected to drive down costs before the retrofit of SJGS is under way.

Moreover, instead of assuming that the cost of retrofitting new carbon capture technology to existing coal-fired generators would decline over time, Enchant and S&L assumed that the cost of retrofitting SJGS with CO₂ capture, the very next

³⁸ Lawrence Berkeley National Laboratory, Utility-Scale Solar – Empirical Trends in Project Technology, Cost, Performance, and PPA Pricing in the United States – 2018 Edition, (Sept. 2018), *available at* https://www.researchgate.net/publication/327607147_Utility-Scale_Solar_Empirical_Trends_in_Project_Technology_Cost_Performance_and_PPA_Pricing_in_the_United_States_-_2018_Edition.

³⁹ U.S. Department of Energy, 2018 Wind Technologies Market Report, (Aug. 2019), *available at* <https://www.energy.gov/sites/prod/files/2019/08/f65/2018%20Wind%20Technologies%20Market%20Report%20FINAL.pdf>.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 commercial-scale power plant in the U.S. to be retrofitted with carbon capture
2 technology, would immediately be 68% lower (on a dollar per kW basis) than the
3 cost of building the Petra Nova plant in Texas.

4 It is possible that the cost of retrofitting SJGS with CO₂ capture will achieve some
5 cost savings from (1) the experience gained at Petra Nova, (2) the reuse of
6 facilities at SJGS and (3) economies of scale. However, it also is quite possible
7 that unanticipated problems will be experienced in scaling up the CO₂ capture
8 technology from the 110 MW Boundary Dam and the 240 MW Petra Nova
9 projects to the much larger 914 MW SJGS.

10 **Q. Are there any other CO₂ capture projects currently being built at**
11 **commercial-scale power plants in the U.S. or that can otherwise be expected**
12 **to come online before the proposed retrofit of SJGS?**

13 A. No, I have not seen evidence of any such projects.

14 **Q. Did Petra Nova gain any cost-related benefits that would not be available to a**
15 **company such as Enchant or PNM that tried to retrofit SJGS with carbon**
16 **capture?**

17 A. Yes. The U.S. Department of Energy provided \$190 million of the \$1 billion cost
18 of building Petra Nova. In addition, approximately 30% of the financing for the
19 project was insured by Nippon Export and Investment Insurance.⁴⁰ Both of these
20 factors reduced the total cost of the project. Mr. Solomon did not provide any
21 evidence that similar funding would be available to retrofit SJGS with carbon
22 capture.

⁴⁰ Noriaki Shimokata, JX Nippon Oil & Gas Exploration Corporation, "Petra Nova CCUS Project in USA," (June 8, 2018), available at <https://d2oc0ihd6a5bt.cloudfront.net/wp-content/uploads/sites/837/2018/06/Noriaki-Shimokata-Petra-Nova-CCUS-Project-in-USA.pdf>.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 **Q. Did the 2019 S&L cost estimate for SJGS exclude any significant costs?**

2 A. Yes. S&L’s 2019 \$1.295 billion capital cost for retrofitting SJGS excluded
3 escalation, AFUDC, right of way and land purchase costs, and site security.⁴¹

4 **Q. Have you seen any CO₂ retrofit cost estimates that would suggest a higher**
5 **capital cost for the SJGS retrofit?**

6 A. Yes. For example, the International Energy Agency, an active advocate for carbon
7 capture, has estimated that the next generation of power plant CCS projects (that
8 is, those after Petra Nova) will achieve 25 to 30 percent reductions in both capital
9 and operating costs.⁴² NARUC has noted that the IEA’s projected reductions in
10 the next generation of power plant CCS reductions, “...support the idea that costs
11 will come down with more facilities.”⁴³

12 Similarly, the Clean Air Task Force (CATF), also an active advocate of CCS,
13 believes that the capital cost of retrofitting existing coal plants for CCS will come
14 down over time as later retrofits “benefit from the prior experience of the earlier
15 projects.”⁴⁴ CATF estimated that the capital cost for retrofits would decline to a
16 range of \$1,501 to \$1,724 per kW by the sixth new project undertaken. However,
17 the SJGS project, would be only the third carbon capture project at a power plant,
18 not the sixth project, as CATF was discussing. And even CATF’s cost estimate
19 for the sixth carbon capture project is higher than the \$1,417 per kW that S&L
20 assumes for SJGS, which as I’ve noted, would be just the third CO₂ retrofit
21 undertaken at a commercial-scale power plant.

⁴¹ Exhibit DS-1 to the Prepared Direct Testimony of Dhiraj Solomon, Appendix D.

⁴² NARUC, Carbon Capture, Utilization, and Storage: Technology and Policy Status and Opportunities at 47 (Nov. 2018), available at <https://pubs.naruc.org/pub/03689F64-B1EB-A550-497A-E0FC4794DB4C>.

⁴³ *Id.*

⁴⁴ CATF, Carbon Capture & Storage in the United States Power Sector: The Impact of 45Q Federal Tax Credits at 24-25 (Feb. 2019), available at https://www.catf.us/wp-content/uploads/2019/02/CATF_CCS_United_States_Power_Sector.pdf.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 **Q. What risks does such an overly optimistic capital cost estimate raise for plant**
2 **owner(s) and investors?**

3 A. Using very low capital cost estimates to entice investors into new projects exposes
4 them to the risk of substantial losses if the actual capital cost of retrofitting a coal-
5 fired generator for CO₂ capture is significantly higher than estimated.

6 **Q. What capital cost would be prudent to use to evaluate a proposed retrofit of**
7 **SJGS with CO₂ capture?**

8 A. Given the great uncertainty regarding the likely capital cost of retrofitting SJGS, it
9 would be prudent to look at a fairly wide range of capital costs. For example, I
10 would recommend looking at a range from a low cost of \$1.40 billion (S&L's
11 2019 estimate in 2023 dollars) to a high cost of \$3.31 billion (25% lower than
12 Petra Nova) with a middle cost of \$2.21 billion (50% of Petra Nova), all in 2023
13 dollars.

14 The low end of these costs represents S&L's 2019 estimate, on a per kW basis,
15 escalated to 2023 dollars. The high end represents a 25% reduction in the actual
16 capital cost of the Petra Nova project, again in 2023 dollars – this reflects the
17 savings that the International Energy Administration has estimated can be
18 expected in the next generation of power plant CCS projects.⁴⁵ Finally, the
19 middle cost reflects a reduction of 50% of the actual Petra Nova capital cost.

20 It is important to emphasize that these costs are conservative and do not represent
21 in any sense a “worst case” scenario in which significant unanticipated difficulties
22 are encountered in scaling-up CO₂ capture technology to the much larger 914
23 MW SJGS project, which could lead to an even higher cost than Petra Nova.

⁴⁵ NARUC, Carbon Capture, Utilization, and Storage: Technology and Policy Status and Opportunities at 47 (Nov. 2018), available at <https://pubs.naruc.org/pub/03689F64-B1EB-A550-497A-E0FC4794DB4C>.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 **IV. It is Extremely Unlikely that a Retrofit of SJGS Could be**
2 **Completed and Come Online before 2024.**

3 **Q. What in-service date has Enchant claimed it will be able to achieve for a**
4 **retrofitted SJGS?**

5 A. Enchant claims that the retrofit of San Juan with CCS could be financed,
6 designed, the carbon capture system competitively bid, constructed, and pre-
7 operationally tested in less than four years, with an online date in June 2023, if the
8 project can be financed by mid-2020.⁴⁶

9 **Q. Do you agree that this schedule is reasonable?**

10 A. No. Enchant's claim about a mid-2023 in-service date is unreasonably optimistic.
11 There simply is too much to do to be able to have the project online so quickly.

12 **Q. Please explain the basis for your conclusion that it is unrealistic to assume**
13 **carbon capture can be completed and online at SJGS by mid-2023.**

14 A. The funding for the FEED (Front End Engineering and Design) study for the
15 retrofit of San Juan with carbon capture has just been approved. Enchant's Project
16 Management Plan for what it terms the "Large-Scale Commercial Carbon Capture
17 Retrofit of the San Juan Generating Station" assumes that the final report for this
18 study will not be submitted to the DOE until mid-April 2021.⁴⁷ Even if enough
19 engineering were completed by mid-April 2021 to start some construction, that
20 would leave only slightly more than two years to competitively bid the CO₂
21 capture system, order, fabricate and deliver system components, then construct
22 and test the CO₂ capture retrofit before it went into service.

⁴⁶ Enchant Energy, Carbon Capture Retrofit of San Juan Generating Station Presentation to San Juan County Community at Slide No. 12 (July 16, 2019), , available at <https://www.enchantenergy.com/wp-content/uploads/2019/07/Enchant-SJGS-Presentation-to-San-Juan-Community-July-2019.pdf>.

⁴⁷ Project Management Plan Large-Scale Commercial Carbon Capture Retrofit of the San Juan Generating Station, Enchant Energy at 7 (May 9, 2019), available at <http://ieefa.org/wp-content/uploads/2019/07/PMP-1.pdf>.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 **Q. How long did it take to design and build the Petra Nova CO₂ capture**
2 **project?**

3 A. The application for DOE funding for the 240 MW Petra Nova project was
4 submitted in 2009, with the DOE grant awarded in 2011. This suggests that
5 design for the project began at least three years before construction. S&L
6 confirms this when it cites its experience working on the Petra Nova project from
7 2011 to 2017.⁴⁸

8 The 240 MW Petra Nova project then began construction in the middle of 2014,
9 and had an online date at the end of 2016, a construction schedule of
10 approximately 2½ years.⁴⁹ Thus Petra Nova had a total project length of about six
11 years, from the awarding of the DOE funding in 2011 to the online date in
12 January 2017.

13 **Q. Do you think it is realistic to assume that a carbon capture project at the 914**
14 **MW SJGS site can be completed in significantly less time than the smaller,**
15 **240 MW project at Petra Nova?**

16 A. No. Enchant is claiming that it could design and build a much larger project (914
17 MW at SJGS versus 240 MW at Petra Nova) in less time, that is, under four years,
18 than it took to design and build Petra Nova, which took six years.⁵⁰ However, it is
19 extremely doubtful that Enchant and S&L's very aggressive June 2023 online
20 date would allow adequate time for the successful completion of what would be a
21 much larger CO₂ capture retrofit project.

22 PNM would be in a similar situation as Enchant if it were to try to retrofit SJGS
23 with carbon capture, meaning that it is extremely unlikely PNM could bring

⁴⁸ Sargent & Lundy, Enchant Energy, San Juan Generating Station – Units 1 & 4 CO₂ Capture Pre-Feasibility Study at 1-2 (July 8, 2019), available at https://www.enchantenergy.com/wp-content/uploads/2019/07/Enchant-Energy_SJGS-CO2-Pre-feasibility-Study_FINAL-Rev-0-7-8.pdf.

⁴⁹ Presentation by Petra Nova Parish Holdings on Petra Nova Carbon Capture at the June 2019 IEA Clean Coal Conference, at slide no. 3.

⁵⁰ Sargent & Lundy, Enchant Energy, San Juan Generating Station – Units 1 & 4 CO₂ Capture Pre-Feasibility Study at 3 (July 8, 2019), available at https://www.enchantenergy.com/wp-content/uploads/2019/07/Enchant-Energy_SJGS-CO2-Pre-feasibility-Study_FINAL-Rev-0-7-8.pdf.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 carbon capture online at SJGS before 2024. Mr. Solomon provides no evidence
2 that PNM (or anyone else) could complete a carbon capture project prior to 2024.

3 **Q. Does Enchant acknowledge that SJGS could return to service later than mid-**
4 **2023?**

5 A. Yes. Enchant has included some wiggle room in the projected online date by
6 saying that the “plant could experience a 6-12 month shut-down before restart
7 with [carbon capture].”⁵¹ This appears to be based on a 30 to 36 month
8 construction schedule and an additional 14-20 months to complete the Front End
9 Engineering Design study.⁵² This would mean an online date for the retrofitted
10 San Juan plan in 2024, which, while still very aggressive, is more realistic than
11 June 2023. This would mean an 18-24 month, or longer, shutdown between the
12 end of 2022 and its restart with carbon capture in 2024 or later.⁵³

13 **Q. Does Mr. Solomon have any evidence that carbon capture can be installed**
14 **and operational prior to January 1, 2023, the deadline by which SJGS must**
15 **meet a CO₂ emissions standard?**

16 A. No. Mr. Solomon admits has no evidence that carbon capture can be installed and
17 operational at SJGS by January 1, 2023, the deadline for meeting the CO₂
18 emission standard in the ETA. Exhibit DAS-2, D. Solomon Depo. Tr. at 75: 6-11.
19 In addition, Mr. Solomon is unaware that Enchant has said that carbon capture
20 cannot be operational at SJGS by January 1, 2023, the deadline for meeting the
21 CO₂ emission standard in the ETA. *Id.* at 75: 12-15.

⁵¹ *Id.*

⁵² Enchant Energy Corporation, Response to Institute for Energy Economics and Financial Analysis report at 3, available at <https://www.enchantenergy.com/wp-content/uploads/2019/07/Enchant-Energy-Corporation-response-to-Institute-for-Energy-Economics-and-Financial-Analysis-IEEFA-report-dated-July-2019.pdf>.

⁵³ My understanding is that the Energy Transition Act requires SJGS to meet a CO₂ emission standard by January 1, 2023. If the carbon capture project does not come online by that date, and no variance or extension of the deadline is granted, then the plant would have to shut down until the carbon capture system is operational and the CO₂ performance standard can be met.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 **Q. Does Mr. Solomon recognize that SJGS must be shut down on January 1,**
2 **2023 if a carbon capture system is not operational on that date?**

3 A. Yes, he does. Mr. Solomon admits that unless carbon capture technology is
4 installed and operational at SJGS, the plant cannot meet the CO₂ emission
5 standard in the ETA that goes into effect on January 1, 2023 and must therefore
6 shut down. Exhibit DAS-2, D. Solomon Depo. Tr. at 35: 14-18, 39: 19 to 40: 20.

7 **Q. By when does Enchant claim that it will have the funding in place for the**
8 **SJGS retrofit?**

9 A. Enchant makes contradictory assumptions about the schedule for developing the
10 financing of the San Juan retrofit as it ties the achievement of a June 2023 online
11 date to acquiring all of the needed financing of the project by June 2020.⁵⁴
12 However, Enchant apparently believes that it will be able to acquire all of the
13 financing needed for the retrofit without demonstrating the financial viability of
14 the project to potential investors as its project plan assumes that the “Feasibility of
15 Coal Plant with CCUS” analysis won’t be completed until April 2021, or nearly
16 ten months after investors are expected to commit well over a billion dollars to the
17 project.⁵⁵ This feasibility study “will determine if the project will move forward
18 into final design and implementation” and would seem to be an important analysis
19 that investors would want to evaluate before they commit to the project.⁵⁶

20 **Q. Why is the date by which carbon capture at SJGS could come online so**
21 **important?**

22 A. The online date for any potential carbon capture project is important for several
23 reasons. First, the longer it takes to build a plant, the greater the impact that

⁵⁴ Enchant Energy, Carbon Capture Retrofit of San Juan Generating Station, Presentation to San Juan County Community at Slide 12 (July 16, 2019), available at <https://www.powermag.com/wp-content/uploads/2019/08/final-enchanted-sjgs-presentation-to-san-juan-community-july-2019.pdf>.

⁵⁵ Project Management Plan Large-Scale Commercial Carbon Capture Retrofit of the San Juan Generating Station, Enchant Energy at PDF page 16 (May 9, 2019), available at <http://ieefa.org/wp-content/uploads/2019/07/PMP-1.pdf>.

⁵⁶ *Id.* at PDF page 10.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 escalation and financing costs will have on the total project cost. Second, the plant
2 owner(s) and/or investors in any San Juan CO₂ capture retrofit would have to pay
3 the plant's fixed costs during any shutdown of San Juan Units 1 and 4 between
4 2022 and its restart with carbon capture, whether in 2023, 2024 or even later.
5 These fixed costs could total as much as \$180 to \$200 million if the retrofitted
6 SJGS units did not restart until mid-2024 and would have to be borne by plant
7 owner(s) and/or investors during a period when the plant would have no incoming
8 revenues as it would not be generating any electricity that could be sold or
9 capturing any CO₂ for sale for EOR.

10 **Q. Have Mr. Solomon or Enchant and S&L accounted in their analyses for the**
11 **costs of having to shut down SJGS for an extended period before the carbon**
12 **capture system could become operational?**

13 A. No. I did not see any place in Mr. Solomon's testimony where he acknowledged
14 the increased costs that any owner(s) would have to bear due to having to shut
15 down SJGS either in 2022 when the current non-Farmington owners want to exit
16 the project or on January 1, 2023 to meet the requirements of the Energy
17 Transition Act. As mentioned above, during any such shutdown, the plant
18 owner(s) would still need to spend money to maintain the plant in good operating
19 condition. In addition, the owner(s) might need to pay for a coal supply, as coal
20 contracts often have "take or pay" clauses that require the buyer to pay for coal
21 even if it is not needed.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 Mr. Solomon does not acknowledge these costs, nor does he explain why he
2 thinks it would be reasonable for PNM to analyze a scenario in which ratepayers
3 would have to pay potentially tens or hundreds of millions of dollars in fixed costs
4 for SJSG to sit idle and not generate any electricity while a CCS system is built.

5 **V. The Cost of Capturing CO₂ at SJGS Can Be Expected to be Much**
6 **Higher Than the Enchant and S&L Cost Estimates that Mr.**
7 **Solomon Relies On.**

8 **Q. Enchant and S&L claim that the cost of capturing CO₂ at SJGS would be**
9 **between \$39.15 and \$43.49 per metric tonne.⁵⁷ Do you agree that this is a**
10 **reasonable range of possible capture costs for a retrofitted SJGS?**

11 A. No.

12 **Q. Please explain.**

13 A. There are several reasons why the range of future CO₂ capacity costs forecast by
14 Enchant and S&L are not realistic.

15 First, the \$39.15 per tonne low end of the range is based on the completely
16 unrealistic assumption that SJGS would operate at a 100% capacity factor, as was
17 discussed earlier in this testimony.

18 Second, and most importantly, the CO₂ capture costs claimed by Enchant and
19 S&L are based on three unreasonable assumptions: (1) that after running at an
20 average 70% capacity factor between 2010 and 2019, SJGS Units 1 and 4 will
21 operate at an average 85% annual capacity factor after being retrofitted; (2) that
22 SJGS will achieve on a sustained basis an unproven 90% CO₂ capture efficiency;
23 and (3) that the cost of retrofitting SJGS will be 68% lower than the cost of
24 designing and building the Petra Nova project.

⁵⁷ See Appendix E to Exhibit DS-1 to the Prepared Direct Testimony of Dhiraj Solomon.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 **Q.** **Have you recalculated what the cost per-tonne of capturing CO₂ would be if**
2 **more reasonable capacity factors, CO₂ capture rates, and capital costs were**
3 **used?**

4 **A.** Yes.

5 **Q.** **What methodology have you used to recalculate the per-tonne SJGS CO₂**
6 **capture costs?**

7 **A.** I used the same methodology as is presented in Appendix E of the S&L July 2019
8 Pre-Feasibility Study. I only modified the analysis to include the 18 scenarios,
9 reflecting reasonable ranges of capacity factors, capture rates and capital costs,
10 that I used in the analysis presented in Table 1, above.

11 **Q.** **What were the results of your analysis?**

12 **A.** The results of my analysis are presented in Table 2, below. As can be seen, the
13 per-tonne capture costs can be expected to be significantly higher than Enchant
14 and S&L are claiming.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

Table 2
Projected SJGS CO₂ Capture Costs

	Scenario Assumptions	CO₂ Capture Cost (Dollars per Metric Tonne)
Corrected Enchant & S&L Proposal	\$1.40 Billion Capital Cost, 85% CF & 90% CO ₂ Capture Rate	\$45.69
Scenario 1	\$1.40 Billion Capital Cost, 70% CF & 80% CO ₂ Capture Rate	\$58.90
Scenario 2	\$1.40 Billion Capital Cost, 70% CF & 70% CO ₂ Capture Rate	\$67.31
Scenario 3	\$1.40 Billion Capital Cost, 70% CF & 60% CO ₂ Capture Rate	\$78.53
Scenario 4	\$2.21 Billion Capital Cost, 70% CF & 80% CO ₂ Capture Rate	\$81.63
Scenario 5	\$2.21 Billion Capital Cost, 70% CF & 70% CO ₂ Capture Rate	\$93.29
Scenario 6	\$2.21 Billion Capital Cost, 70% CF & 60% CO ₂ Capture Rate	\$108.84
Scenario 7	\$3.31 Billion Capital Cost, 70% CF & 80% CO ₂ Capture Rate	\$112.84
Scenario 8	\$3.31 Billion Capital Cost, 70% CF & 70% CO ₂ Capture Rate	\$128.97
Scenario 9	\$3.31 Billion Capital Cost, 70% CF & 60% CO ₂ Capture Rate	\$150.46
Scenario 10	\$1.40 Billion Capital Cost, 47% CF & 80% CO ₂ Capture Rate	\$79.69
Scenario 11	\$1.40 Billion Capital Cost, 47% CF & 70% CO ₂ Capture Rate	\$91.07
Scenario 12	\$1.40 Billion Capital Cost, 47% CF & 60% CO ₂ Capture Rate	\$106.25
Scenario 13	\$2.21 Billion Capital Cost, 47% CF & 80% CO ₂ Capture Rate	\$113.54
Scenario 14	\$2.21 Billion Capital Cost, 47% CF & 70% CO ₂ Capture Rate	\$129.76
Scenario 15	\$2.21 Billion Capital Cost, 47% CF & 60% CO ₂ Capture Rate	\$151.39
Scenario 16	\$3.31 Billion Capital Cost, 47% CF & 80% CO ₂ Capture Rate	\$160.03
Scenario 17	\$3.31 Billion Capital Cost, 47% CF & 70% CO ₂ Capture Rate	\$182.89
Scenario 18	\$3.31 Billion Capital Cost, 47% CF & 60% CO ₂ Capture Rate	\$213.38

Q. Why is the Base Case capture cost in Table 1 (\$45.69 per metric tonne) higher than the \$43.49 cost in Appendix E of S&L's July 2019 Pre-Feasibility Study?

A. The Total Project Cost that S&L used in its analysis to calculate the cost of CO₂ capture is in 2019 dollars. I escalated this cost to 2023 dollars as that is what Enchant is claiming could be the online date for the retrofitted SJGS.

Q. Why are the CO₂ capture costs in Table 1, above, so much higher than the costs claimed by Enchant and S&L even in the scenarios which use the S&L estimated capital cost?

A. Assuming more realistic plant capacity factors and CO₂ capture rates means that the plant will capture millions fewer tonnes of CO₂ so the capital cost of the retrofit and the fixed CO₂ capture O&M costs would be spread over fewer tonnes of CO₂ – see Figure 12, above. This means a higher cost of capture per tonne.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 **VI. Any Owner(s) of SJGS Can Expect to Suffer Substantial Losses in**
2 **the Sale of Electricity after 2023.**

3 **Q. Did Staff Witness Solomon discuss the risks that any SJGS owner(s) and/or**
4 **investors would have to pay for maintenance that had been deferred by the**
5 **current owners and for the plant's fixed O&M costs if the plant closes in**
6 **2022 and is then restarted following the completion of the CO₂ capture**
7 **retrofit?**

8 A. No.

9 **Q. Are there any other significant risks that also should be considered when**
10 **evaluating whether retrofitting SJGS is feasible?**

11 A. Yes. The analysis must consider whether the electricity generated at the plant will
12 be sold at prices at least equal to the costs of producing that electricity.

13 **Q. Is it reasonable to expect that any owner(s) of SJGS will be able to sell the**
14 **electricity it produces at a profit?**

15 A. No. It is far more likely that SJGS's owner(s) would incur substantial losses in the
16 sale of the plant's electricity.

17 **Q. What is the basis for this conclusion?**

18 A. SJGS Units 1 and 4 cannot be expected to be low cost-generators after being
19 retrofitted for CO₂ capture, contrary to Enchant's claim.⁵⁸


20 **Q. What do the current owners of SJGS project for the future costs of**
21 **generating electricity at SJGS if the plant is not retired in 2022?**

22 A. PNM and TEP have both forecasted that SJGS will continue to be a high-cost
23 generator if the plant is not retired in 2022, as shown in Figure 14, below:

⁵⁸ Enchant Energy, The Economic Case for Power Plant Carbon Capture Retrofits: A Case Study on the San Juan Generating Station – New Mexico, (Sept. 12, 2019), *available at* https://www.usea.org/sites/default/files/event-/USEA%202019%20ESF_Selch.pdf.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

Figure 14: PNM and TEP Projected SJGS Operating and Maintenance Costs vs. Market Prices



Sources: Forward Energy Market Prices downloaded from S&P Global Market Intelligence on November 1, 2019; Tucson Electric Power's projected SJGS costs of energy are from the company's April 28, 2018 response to the Notice of Inquiry in Arizona Corporation Commission Docket No. E-00000Q-16-0289; and PNM's projected costs are from the output reports provided in response to Data Request NEE 1-72.

Q. Do the other SJGS owners agree that the plant is not a low-cost generator and will not become one in the future?

A. The City of Farmington doesn't, and I was unable to find any information about the expectations of the Utah Associated Municipal Power Systems. However, Los Alamos County does not consider SJGS to be a low-cost generator and expects the plant's cost of electricity to remain expensive if it is not retired in 2022, as was noted in a 2017 Integrated Resource Plan Report (IRP) prepared for the County: "SJGS 4 incurs high fixed costs and is not economic to dispatch under current market conditions."⁵⁹


⁵⁹ Pace Global, 2017 Integrated Resource Plan Report prepared for Los Alamos County at 46 (June 30, 2017), available at <https://losalamosnm.us/common/pages/DisplayFile.aspx?itemId=14454077>.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

The Los Alamos County IRP also included an exhibit that illustrated the plant's high costs.

Figure 15: Los Alamos County Projected SJGS Operating & Maintenance Costs

Exhibit 37: SJGS 4 Costs and Market Prices Comparison



Note: SJGS 4 runs at minimum level during 2017-2033.
Source: Pace Global.

Source: 2017 Integrated Resource Plan prepare for Los Alamos Country, August 1, 2017, at page 46.⁶⁰

Q. Do the O&M projections in Figures 14 and 15 reflect a retrofit of SJGS to capture CO₂?

A. No.

Q. What impact could such a retrofit be expected to have on the plant's non-CO₂ capture costs?

A. With a carbon capture retrofit, SJGS's average per MWh non-CO₂ capture costs would be higher than is shown in Figures 14 and 15. This is due to the very high parasitic loads due to the internal plant power that is used to run the CO₂ capture equipment. This high parasitic load would decrease the plant's net capacity from 847 MW pre-retrofit to just 601 MW post-retrofit. This means that the plant's

⁶⁰ Available at <https://losalamosnm.us/common/pages/DisplayFile.aspx?itemId=14454077>.


Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

non-CO₂ capture-related fixed O&M costs must be spread over fewer MWh of output, and this raises the cost of each MWh that the owner(s) would be seeking to sell. As a result, electricity from SJGS would be even more expensive and less competitive than Figures 14 and 15 suggest.

Q. But doesn't Enchant claim that there will be cost savings from an improved coal contract?

A. Yes, Enchant does make that claim.⁶¹ However, PNM's projected O&M costs presented in Figure 14 and included in my analysis already reflect that SJGS's future coal prices are expected to be much lower than they have been in recent years, as shown in Figure 16, below:

Figure 16: SJGS's Recent vs. Projected Coal Costs



Sources: PNM FERC Form 1 Filings and Scenario 1 Output Reports provided in PNM's Expedited Response to NEE Interrogatory 1-72 in Case 19-00018-UT

⁶¹ [Carbon Capture Retrofit of San Juan Generating Station, Presentation to San Juan County Community](https://www.powermag.com/wp-content/uploads/2019/08/final-enchant-sjgs-presentation-to-san-juan-community-july-2019.pdf), July 16, 2019, at Slide 4, available at <https://www.powermag.com/wp-content/uploads/2019/08/final-enchant-sjgs-presentation-to-san-juan-community-july-2019.pdf>.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 **Q. What is the range of potential losses that you have calculated that the**
2 **owner(s) of SJGS can reasonably be expected to suffer from the sale of**
3 **electricity in the years 2024-2035, if SJS were retrofit with carbon capture**
4 **technology?**

5 A. The owner(s) of SJGS can expect to experience losses of between \$474 and \$704
6 million from the sale of high-cost electricity produced at SJGS during the years
7 2024-2035.

8 **Q. Do these losses include the cost impact of any capital expenditures that**
9 **owner(s) would have to spend on CO₂ capture or balance-of-plant**
10 **maintenance or repairs?**

11 A. No. In my experience coal plant owner(s) typically spend on maintenance-related
12 capex projects until the plants are near retirement. However, the amounts they
13 spend are very plant-specific. I have not included in this analysis any estimate of
14 what those costs might be for SJGS for CO₂ capture or balance-of-plant
15 maintenance or repairs. My estimated range of potential losses is, then,
16 conservative or low.

17 **VII. The Owner(s) of SJGS Would Be Exposed to Oil Market**
18 **Volatility and Risks if They Retrofit SJGS with Carbon Capture**
19 **Technology.**

20 **Q. Are the market values for CO₂ cited by Mr. Solomon at page 15, lines 17-18,**
21 **of his Prepared Direct Testimony prices that any owner(s) of SJGS would be**
22 **guaranteed to receive for the sale of the CO₂ captured at the plant?**

23 A. No. They are simply projected values based on one of the oil price forecasts
24 included in the EIA's 2018 Annual Energy Outlook. There is no guarantee that
25 actual CO₂ prices will be anywhere near these values, or even as high as the
26 \$17.50 per tonne price assumed by Enchant and S&L in their marketing materials
27 for the SJGS retrofit.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 **Q. What factors are likely to determine future CO₂ prices?**

2 A. It is reasonable to expect that future CO₂ prices most likely will be affected by
3 actual and expected oil prices and by the competition between different CO₂
4 sources.

5 **Q. Have you seen any evidence that changing oil markets have rendered Petra**
6 **Nova less profitable than NRG anticipated when it undertook the project?**

7 A. Yes. Although using the CO₂ captured at Petra Nova for enhanced oil recovery
8 has increased the amount of oil produced at the company's West Ranch oil field,
9 it appears that the project has not been nearly as profitable as NRG expected when
10 it was adding carbon capture to the existing W.A. Parish coal-fired generator in
11 Houston.

12 In 2016, NRG took an impairment of \$140 million on its \$300 million investment
13 in its subsidiary Petra Nova Parish Holdings due to a continued decline in oil
14 prices.⁶² NRG then took another impairment of \$69 million in its investment in
15 Petra Nova in 2017 based on a revised view of oil production expectations.⁶³

16 Even though Petra Nova was completed on schedule and on budget, in October
17 2016, even before the project began operations, NRG said that the project would
18 be its last clean coal plant due to a drop in oil prices.⁶⁴ Fortune Magazine noted
19 that NRG Energy's Petra Nova project "may be completed, but it's unlikely to set
20 a precedent for profitability."⁶⁵

⁶² NRG Energy, Inc., NRG 10-K for the Year Ended December 31, 2016 at 170, *available at* <https://investors.nrg.com/node/25486/html>.

⁶³ NRG Energy, Inc., NRG 10-K for the Year Ended December 31, 2017 at 164, *available at* <https://investors.nrg.com/static-files/7f12dcd9-bc0b-40c7-87aa-78f8616d663e>.

⁶⁴ Fortune Magazine, "What Donald Trump Didn't Mention About Clean Coal," October 10, 2016, *available at* <https://fortune.com/2016/10/10/donald-trump-clean-coal/>.

⁶⁵ *Id.*

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 **Q.** Should this Petra Nova project experience serve as a warning to the owners
2 of SJGS and potential investors in retrofitting the plant with carbon
3 capture?

4 **A.** Yes.

5 **Q.** Finally, even if SJGS did capture 6 million tonnes of CO₂ each year, would
6 this mean that the overall emissions into the atmosphere would decline by 6
7 million tonnes?

8 **A.** No. The use of captured CO₂ for EOR produces additional oil that, in turn, is
9 burned or used as a chemical feedstock, both of which can be expected to release
10 CO₂ into the atmosphere. For example, *Power Magazine* estimates that every ton
11 of CO₂ used in EOR will bring up roughly 0.76 to 0.91 tons of equivalent CO₂
12 that will ultimately end up in the atmosphere.⁶⁶ And even this might not capture
13 all of the CO₂ emitted by the additional oil produced with EOR.

14 **VIII. Conclusions**

15 **Q.** Please summarize your testimony.

16 **A.** In arguing that PNM should have conducted a new analysis of continuing to
17 operate SJGS with carbon capture, Mr. Solomon did not produce his own analysis
18 of the engineering, economic, or financial feasibility of carbon capture at the
19 plant. Instead, Mr. Solomon relies on claims made by Enchant and S&L. But the
20 SJGS retrofit proposal submitted by Enchant Energy relies on a series of
21 assumptions that are little more than wishful thinking. Enchant's proposal hinges
22 on the assumption that the retrofitted facility would be able to capture 6 million
23 metric tonnes of carbon annually—a number that simply cannot be achieved. To
24 capture that much carbon each year would require the facility to capture 90% of

⁶⁶ PowerMag, "Is EOR a Dead End for Carbon Capture and Storage?," April 12, 2016, available at <https://www.powermag.com/is-eor-a-dead-end-for-carbon-capture/>.

Case No. 19-00018-UT
Prepared Rebuttal Testimony of
David A. Schlissel

1 the CO₂ it produces and operate at an annual capacity factor of at least 85% for 12
2 years, both of which are unrealistic.

3 As my testimony has shown, the only two existing power plants in the world that
4 capture CO₂ have not captured 90% of their CO₂ emissions, and it is unrealistic to
5 expect that carbon capture at SJGS could do so either. Equally important, it is
6 totally unrealistic to assume that the retrofitted SJGS facility would be able to
7 achieve an annual capacity factor of at least 85% for the first 12 years of its
8 operation when neither of the two units at the plant have hit that level since 2011.
9 Age-related reliability issues and competition from renewable energy resources
10 are almost certain to prevent the plant from operating anywhere near the 85%
11 level assumed by Enchant.

12 Beyond these two problems, the Enchant proposal significantly understates the
13 project's probable capital cost, assuming reductions from the first two units that
14 are not tenable. Moreover, Enchant's claims as to when carbon capture could
15 come online at SJGS are unlikely to be met. As this testimony has shown, more
16 realistic assumptions about the construction costs and commercial completion
17 date would substantially increase the project's cost, making it financially unviable
18 from the outset.

19 **Q. Consequently, do you agree with Mr. Solomon that carbon capture and**
20 **sequestration is an economically and financially feasible option at SJGS that**
21 **should have been analyzed in PNM's abandonment application?**

22 A. No. Based on the evidence I have reviewed and the analyses I presented above, I
23 do not believe that carbon capture and sequestration is financially feasible at
24 SJGS. For the same reasons, I disagree with Mr. Solomon that a scenario
25 involving carbon capture should have been modeled by PNM.

26 **Q. Does this complete your testimony?**

27 A. Yes.

28

BEFORE THE NEW MEXICO PUBLIC REGULATION COMMISSION

IN THE MATTER OF PUBLIC SERVICE
COMPANY OF NEW MEXICO'S
ABANDONMENT OF SAN JUAN
GENERATING STATION UNITS 1 AND 4

)
)
) Case No. 19-00018-UT
)

VERIFICATION

STATE OF MASSACHUSETTS }

COUNTY OF Middlesex }

David A. Schlissel, first being sworn on his oath, states:

I am the witness identified in the preceding rebuttal testimony. I have read the rebuttal testimony and am familiar with the contents. Based upon my personal knowledge, the facts stated in the rebuttal testimony are true. In addition, in my judgment and based upon my professional experience, the opinions and conclusions stated in the rebuttal testimony are true, valid, and accurate.

David A. Schlissel
David A. Schlissel

SUBSCRIBED AND SWORN TO before me on this 18 day of November, 2019 by David A. Schlissel.

Notary Public

My commission expires: NOV 20, 2021



MAURICIO BURGOS
Notary Public
Commonwealth of Massachusetts
My Commission Expires November 20, 2021